

PROBLEM SUMMARY

8662844 (S/N 2443)


Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Sample Rating Trend ISO New York 273

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

| PROBLEMATIC TEST RESULTS | | | | | | | | |
|--------------------------|--------------|---------|-----------------|--|--|--|--|--|
| Sample Status | | | ABNORMAL | | | | | |
| Particles >6μm | ASTM D7647 | >1300 | A 8127 | | | | | |
| Particles >14µm | ASTM D7647 | >80 | 903 | | | | | |
| Particles >21µm | ASTM D7647 | >20 | 183 | | | | | |
| Oil Cleanliness | ISO 4406 (c) | >/17/13 | 21/20/17 | | | | | |

Customer Id: BARENG Sample No.: KCPA003812 Lab Number: 06015101 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS




OIL ANALYSIS REPORT

8662844 (S/N 2443)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)



DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| | | | | Nov2023 | | |
|------------------|----------|---------------|------------|-------------|----------|----------|
| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 |
| Sample Number | | Client Info | | KCPA003812 | | |
| Sample Date | | Client Info | | 15 Nov 2023 | | |
| Machine Age | hrs | Client Info | | 3978 | | |
| Oil Age | hrs | Client Info | | 0 | | |
| Oil Changed | | Client Info | | N/A | | |
| Sample Status | | | | ABNORMAL | | |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | <1 | | |
| Chromium | ppm | ASTM D5185m | >10 | <1 | | |
| Nickel | ppm | ASTM D5185m | >3 | 0 | | |
| Titanium | ppm | ASTM D5185m | >3 | 0 | | |
| Silver | ppm | ASTM D5185m | >2 | <1 | | |
| Aluminum | ppm | ASTM D5185m | >10 | 1 | | |
| Lead | ppm | ASTM D5185m | >10 | 0 | | |
| Copper | ppm | ASTM D5185m | >50 | 1 | | |
| Tin | ppm | ASTM D5185m | >10 | 0 | | |
| Vanadium | ppm | ASTM D5185m | | 0 | | |
| Cadmium | ppm | ASTM D5185m | | 0 | | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | 0 | 0 | | |
| Barium | ppm | ASTM D5185m | 90 | 38 | | |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | | |
| Manganese | ppm | ASTM D5185m | | 0 | | |
| Magnesium | ppm | ASTM D5185m | 100 | 93 | | |
| Calcium | ppm | ASTM D5185m | 0 | 2 | | |
| Phosphorus | ppm | ASTM D5185m | 0 | 0 | | |
| Zinc | ppm | ASTM D5185m | 0 | 0 | | |
| Sulfur | ppm | ASTM D5185m | 23500 | 19922 | | |
| CONTAMINANTS | 3 | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | <1 | | |
| Sodium | ppm | ASTM D5185m | 725 | 7 | | |
| Potassium | | ASTM D5185m | >20 | 6 | | |
| Water | ppm % | ASTM D5165111 | >0.05 | 0.015 | | |
| ppm Water | ppm | ASTM D6304 | >500 | 154 | | |
| FLUID CLEANLIN | | method | limit/base | current | history1 | history2 |
| Particles >4µm | | ASTM D7647 | | 17095 | | |
| Particles >6µm | | ASTM D7647 | >1300 | ▲ 8127 | | |
| Particles >14µm | | ASTM D7647 | >80 | ▲ 903 | | |
| Particles >21μm | | ASTM D7647 | | ▲ 183 | | |
| Particles >38μm | | ASTM D7647 | >4 | 4 | | |
| Particles >71μm | | ASTM D7647 | | 0 | | |
| Oil Cleanliness | | ISO 4406 (c) | >/17/13 | △ 21/20/17 | | |
| FLUID DEGRADA | ATION | method | limit/base | | hictory | history? |
| | | | | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 1.0 | 0.37 | | |



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: KCPA003812 : 06015101 : 10754245

Received : 22 Nov 2023 Diagnosed

: 24 Nov 2023 Diagnostician : Doug Bogart

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

1952 W UNION AVE UNIT B

ENGLEWOOD, CO US 80110

Contact: Service Manager

T: F: