

## **PROBLEM SUMMARY**

Sample Rating Trend

ISO

Machine Id


# KAESER ASD 25 4022787 (S/N 1490)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

#### **COMPONENT CONDITION SUMMARY**



#### RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL		
Particles >6μm	ASTM D7647	>1300	<u> 52501</u>		<u></u> 5552		
Particles >14μm	ASTM D7647	>80	<b>△</b> 5987		<b>△</b> 275		
Particles >21µm	ASTM D7647	>20	<b>1788</b>		<b>△</b> 69		
Particles >38μm	ASTM D7647	>4	<b>▲</b> 68		1		
Particles >71μm	ASTM D7647	>3	<u>^</u> 5		0		
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>24/23/20</b>		22/20/15		

Customer Id: PERHOU Sample No.: KC124385 Lab Number: 06015109 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

#### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

#### HISTORICAL DIAGNOSIS

#### 26 May 2023 Diag: Don Baldridge

#### VIS DEBRIS



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 12 Jan 2023 Diag: Angela Borella

150



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 15 Aug 2022 Diag: Jonathan Hester

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





## **OIL ANALYSIS REPORT**

**ADDITIVES** 

Acid Number (AN)

Sample Rating Trend



# **KAESER ASD 25 4022787 (S**

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

### **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

(S/N 1490)		p2011 Ma20	3 October 1 Novicos	Oczóli Majčila Majčolo Ja	1022 - Resid	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC124385	KC101452	KC108486
Sample Date		Client Info		17 Nov 2023	26 May 2023	12 Jan 2023
Machine Age	hrs	Client Info		87436	84058	80843
Oil Age	hrs	Client Info		0	6000	3000
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1

WEAR METALS		method	iimit/base	current	nistory i	nistory2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	<1	<1	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	<1	<1	0
Aluminum	ppm	ASTM D5185m	>10	1	<1	0
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	9	12	4
Tin	ppm	ASTM D5185m	>10	0	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

					,	,
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	6	11	22
Calcium	ppm	ASTM D5185m	2	<1	0	0
Phosphorus	ppm	ASTM D5185m		0	0	3
Zinc	ppm	ASTM D5185m		17	14	18

current

history1

method limit/base

CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		2	2	9
Potassium	ppm	ASTM D5185m	>20	2	<1	1
Water	%	ASTM D6304	>0.05	0.020	0.003	0.011
ppm Water	ppm	ASTM D6304	>500	205	27.0	117.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		141800		26179
Particles >6µm		ASTM D7647	>1300	<u> 52501</u>		<u></u> 5552
Particles >14µm		ASTM D7647	>80	<b>5987</b>		<b>△</b> 275

Particles >14µm	ASTM D7647	>80	<b>△</b> 5987		<u>△</u> 275
Particles >21µm	ASTM D7647	>20	<u> </u>		<b>△</b> 69
Particles >38μm	ASTM D7647	>4	<b>▲</b> 68		1
Particles >71µm	ASTM D7647	>3	<u> 5</u>		0
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u>4</u> 24/23/20		<u>22/20/15</u>
FLUID DEGRADATION	method	limit/base	current	history1	history2

0.32


mg KOH/g ASTM D8045 0.4

0.38

0.36



### **OIL ANALYSIS REPORT**





Certificate L2367

Test Package

: IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

Contact: SERVICE MANAGER