

## **PROBLEM SUMMARY**

#### Machine Id KAESER SK 15T 5648101 (S/N 1698) Component

Compressor Fluic

KAESER SIGMA (OEM) FG-460 (--- GAL)

## COMPONENT CONDITION SUMMARY









### RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

THOBELIN THO I		00210				
Sample Status				ABNORMAL	NORMAL	ABNORMAL
Iron	ppm	ASTM D5185m	>50	<u> </u>	<1	12
Aluminum	ppm	ASTM D5185m	>10	<b>1</b> 0	<1	<b>1</b> 9
Particles >6µm		ASTM D7647	>1300	<b>69672</b>	310	522
Particles >14µm		ASTM D7647	>80	<b>6</b> 5786	45	20
Particles >21µm		ASTM D7647	>20	<u> </u>	15	3
Particles >38µm		ASTM D7647	>4	<u> </u>	1	1
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	17/15/13	19/16/11

Customer Id: BALENG Sample No.: KC125939 Lab Number: 06015117 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Resample			?	We recommend an early resample to monitor this condition.		

## HISTORICAL DIAGNOSIS





Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 07 Sep 2022 Diag: Doug Bogart

06 Jun 2023 Diag: Don Baldridge

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



## 06 May 2022 Diag: Don Baldridge

Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





view report



## **OIL ANALYSIS REPORT**

# KAESER SK 15T 5648101 (S/N 1698)

Compressor Fluid

KAESER SIGMA (OEM) FG-460 (--- GAL)

## DIAGNOSIS

## Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

## 🔺 Wear

The iron level is abnormal. The aluminum level is abnormal.

## Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC125939	KC123073	KC89536
Sample Date		Client Info		06 Nov 2023	06 Jun 2023	07 Sep 2022
Machine Age	hrs	Client Info		20875	18551	13175
Oil Age	hrs	Client Info		0	0	2870
Oil Changed		Client Info		N/A	N/A	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	62	<1	12
Chromium	mag	ASTM D5185m	>10	<1	<1	0
Nickel	mag	ASTM D5185m	>3	0	1	0
Titanium	mag	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>10	<u> </u>	<1	<u> </u>
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	3	3	2
Tin	ppm	ASTM D5185m	>10	0	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	nom	ASTM D5185m		0	0	0
Barium	mag	ASTM D5185m		0	0	0
Molvbdenum	maa	ASTM D5185m		0	0	0
Manganese	mag	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		2	<1	0
Calcium	ppm	ASTM D5185m		<1	0	0
Phosphorus	ppm	ASTM D5185m	500	445	473	452
Zinc	ppm	ASTM D5185m		204	132	263
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	nnm	ASTM D5185m	>25	0	~1	0
Sodium	nnm	ASTM D5185m	225	0	2	0
Potassium	ppm	ASTM D5185m	>20	1	3	0
Water	%	ASTM D6304	>0.05	0.008	0.005	0.005
ppm Water	ppm	ASTM D6304	>500	81	59.0	53.6
FLUID CLEANLIN	ESS	method	limit/base	current	historv1	historv2
Particles \/um				123200	1091	2516
Particles >4µm		ASTM D7647	<1300	69672	310	522
Particles >0µm		ASTM D7647	>1000	A 5786	45	20
Particles >14µm		ASTM D7647	>20	A 885	15	3
Particles >38um		ASTM D7647	>4	<u> </u>	1	1
Particles >71um		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 24/23/20	17/15/13	19/16/11
		mothed	limit/baca	ourroot	historyd	history
					1 OF	
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	0.82	1.35	0.99



140

120

80

60

40k

20

0

60

50

4(

E 30 20

10

12000

1000

200

60

50

4(

E 30

20

2.00

0 her Acid 1

0.0

Ξ.

S

KOH/g)

Water (ppm) 600 lov1

〒100

## **OIL ANALYSIS REPORT**

limit/base

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

limit/base

limit/base

>0.05

46

current

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

curren

current

NEG

NEG

46.6

history1

NONE

NONE

NONE

NONE

LIGHT

NONE

NORML

NORML

history

history1

NEG

NEG

47.0

history2

LIGHT

NONE

NONE

NONE

NONE

NONE

NORML

NORML

history2

history2

NEG

NEG

46.0







**BALTHAZER BAKERY** 214 S DEAN ST ENGLEWOOD, NJ US 07631 Contact:

Sep7/22

lan4/22

Jan 13/21

Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Page 4 of 4

<sup>\* -</sup> Denotes test methods that are outside of the ISO 17025 scope of accreditation.