OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Area
SLAUGHTER
Machine Id
SULLAIR TYSAMAS 3 SUL (S/N 007-95000489)
Component
Refrigeration Compressor
Fluid
USPI 1009-68 SC (--- GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**USP0003563**	USPM29033	USP0001046
Sample Date		Client Info		**14 Nov 2023**	26 Jul 2023	21 Jul 2023
Machine Age	hrs	Client Info		**12717**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**NORMAL**	NORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	**0**	---	<1
Chromium	ppm	ASTM D5185m	>2	**0**	---	0
Nickel	ppm	ASTM D5185m		**0**	---	0
Titanium	ppm	ASTM D5185m		**0**	---	0
Silver	ppm	ASTM D5185m	>2	**0**	---	0
Aluminum	ppm	ASTM D5185m	>3	**0**	---	0
Lead	ppm	ASTM D5185m	>2	**0**	---	0
Copper	ppm	ASTM D5185m	>8	**0**	---	0
Tin	ppm	ASTM D5185m	>4	**0**	---	0
Vanadium	ppm	ASTM D5185m		**0**	---	0
Cadmium	ppm	ASTM D5185m		**0**	---	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	---	0
Barium	ppm	ASTM D5185m		**0**	---	1
Molybdenum	ppm	ASTM D5185m		**0**	---	0
Manganese	ppm	ASTM D5185m		**<1**	---	0
Magnesium	ppm	ASTM D5185m		**<1**	---	0
Calcium	ppm	ASTM D5185m		**0**	---	<1
Phosphorus	ppm	ASTM D5185m		**0**	---	0
Zinc	ppm	ASTM D5185m		**0**	---	0
Sulfur	ppm	ASTM D5185m	50	**0**	---	24

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	**0**	---	0
Sodium	ppm	ASTM D5185m		**0**	---	0
Potassium	ppm	ASTM D5185m	>20	**0**	---	<1
Water	%	ASTM D6304	>0.01	**0.004**	---	0.003
ppm Water	ppm	ASTM D6304	>100	**44**	---	37.5

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		**5314**	---	4522
Particles >6µm		ASTM D7647	>2500	**1614**	---	1358
Particles >14µm		ASTM D7647	>320	**74**	---	60
Particles >21µm		ASTM D7647	>80	**7**	---	5
Particles >38µm		ASTM D7647	>20	**0**	---	0
Particles >71µm		ASTM D7647	>4	**0**	---	0
Oil Cleanliness		ISO 4406 (c)	>--/18/15	**20/18/13**	---	19/18/13

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	**0.01**	---	0.015

OIL ANALYSIS REPORT











VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	---	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	---	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	---	NONE
Silt	scalar	*Visual	NONE	**NONE**	---	NONE
Debris	scalar	*Visual	NONE	**LIGHT**	---	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	---	NONE
Appearance	scalar	*Visual	NORML	**NORML**	---	NORML
Odor	scalar	*Visual	NORML	**NORML**	---	NORML
Emulsified Water	scalar	*Visual	>0.01	**NEG**	---	NEG
Free Water	scalar	*Visual		**NEG**	---	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	67	**68.6**	---	69.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS











Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USP0003563
Lab Number : 06015152
Unique Number : 10754296
Test Package : IND 2

Received : 22 Nov 2023
Diagnosed : 24 Nov 2023
Diagnostician : Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

TYSON -AMARILLO-USP

AMARILLO, TX
US
Contact: RANDY INGRAM

T: (806)355-7732
F: (806)352-6946