


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



37 HSC ER6 (S/N W0940VFMCLHAA03)

Refrigeration Compressor

FRICK 19 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

cv bn,./All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Apr2021 A	ug2021 Jan2022 Apr203	2 Oct2022 Feb2023 Jul2023	Nov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0003537	USP250057	USP246728
Sample Date		Client Info		10 Nov 2023	08 Jul 2023	25 Feb 2023
Machine Age	hrs	Client Info		10225	9084	8508
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	0
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	<1	0
Lead	ppm	ASTM D5185m	>2	0	<1	0
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		<1	0	0
Calcium	ppm	ASTM D5185m		1	0	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		0	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	1	1
Sodium	ppm	ASTM D5185m		0	0	<1
Potassium	ppm	ASTM D5185m		0	<1	0
Water	%	ASTM D6304	>0.01	0.003	0.007	0.002
ppm Water	ppm	ASTM D6304	>100	36	77.0	24.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	1520	1372	1022
Particles >6µm		ASTM D7647	>2500	451	465	267
Particles >14μm		ASTM D7647	>320	21	15	14
Particles >21µm		ASTM D7647	>80	4	1	5
Particles >38μm		ASTM D7647	>20	0	0	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	18/16/12	18/16/11	17/15/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974		0.01	0.012	0.014



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: 06015170

: USP0003537 : 10754314 Test Package : IND 2

Received : 22 Nov 2023

Diagnosed : 26 Nov 2023 Diagnostician : Doug Bogart 601 N CHURCH ST SMITHFIELD, VA US 23430

Contact:

T: F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)