




PROBLEM SUMMARY

Sample Rating Trend

ISO




Machine Id
SMISMI 23 ER4 (S/N S0017EFMCLHBA3)

Component
Refrigeration Compressor
Fluid
USPI 1009-68 SC (250 GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>10000	▲ 56894	▲ 46475	▲ 10838
Particles >6µm	ASTM D7647	>2500	▲ 6399	▲ 5547	653
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 23/20/12	▲ 23/20/13	▲ 21/17/10

Customer Id: SMISMNP
Sample No.: USP0003536
Lab Number: 06015171
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

04 May 2022 Diag: Doug Bogart

VISCOSITY



We recommend that you drain the oil and perform a filter service on this component if not already done. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The oil viscosity is higher than normal. Confirmed. The AN level is acceptable for this fluid. The oil is no longer serviceable.

view report



08 Jan 2022 Diag: Doug Bogart

VISCOSITY



We recommend that you drain the oil and perform a filter service on this component if not already done. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 6 microns in size) present in the oil. The oil viscosity is higher than normal. Confirmed. The AN level is acceptable for this fluid. The oil is no longer serviceable.

view report



22 Aug 2021 Diag: Jonathan Hester

VISCOSITY



We recommend that you drain the oil and perform a filter service on this component if not already done. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The oil viscosity is higher than normal. Confirmed. The AN level is acceptable for this fluid. The oil is no longer serviceable.

view report





OIL ANALYSIS REPORT


Sample Rating Trend

ISO



Machine Id
SMISMI 23 ER4 (S/N S0017EFMCLHBA3)

Component
Refrigeration Compressor
Fluid
USPI 1009-68 SC (250 GAL)



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service. Elements confirmed.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		USP0003536	USP221617	USP236214
Sample Date	Client Info		14 Nov 2023	04 May 2022	08 Jan 2022
Machine Age	hrs	Client Info	18433	114770	113017
Oil Age	hrs	Client Info	16	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >8	15	21	19
Chromium	ppm	ASTM D5185m >2	0	<1	<1
Nickel	ppm	ASTM D5185m	0	<1	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m >2	0	<1	<1
Aluminum	ppm	ASTM D5185m >3	0	<1	<1
Lead	ppm	ASTM D5185m >2	0	0	0
Copper	ppm	ASTM D5185m >8	<1	<1	<1
Tin	ppm	ASTM D5185m >4	0	0	0
Antimony	ppm	ASTM D5185m	---	---	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<1	<1
Barium	ppm	ASTM D5185m	<1	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	<1
Manganese	ppm	ASTM D5185m	0	<1	<1
Magnesium	ppm	ASTM D5185m	0	<1	<1
Calcium	ppm	ASTM D5185m	13	27	26
Phosphorus	ppm	ASTM D5185m	6	17	20
Zinc	ppm	ASTM D5185m	10	11	9
Sulfur	ppm	ASTM D5185m 50	116	248	197

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	0	<1	<1
Sodium	ppm	ASTM D5185m	3	2	1
Potassium	ppm	ASTM D5185m >20	0	0	0
Water	%	ASTM D6304 >0.01	0.006	0.004	0.003
ppm Water	ppm	ASTM D6304 >100	69	46.9	26.5


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 56894	▲ 46475	▲ 10838
Particles >6µm	ASTM D7647	>2500	▲ 6399	▲ 5547	653
Particles >14µm	ASTM D7647	>320	33	54	10
Particles >21µm	ASTM D7647	>80	4	4	2
Particles >38µm	ASTM D7647	>20	0	0	0
Particles >71µm	ASTM D7647	>4	0	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 23/20/12	▲ 23/20/13	▲ 21/17/10


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974 0.005	0.04	0.027	0.027


▲ Particle Trend




Water (KF)




Acid Number



Water (KF)




Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	VLITE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 67	74.3	▲ 82.5	▲ 83.5

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : USP0003536
 Lab Number : 06015171
 Unique Number : 10754315
 Test Package : IND 2

SMITHFIELD FOODS - NORTH PLANT
 601 N CHURCH ST
 SMITHFIELD, VA
 US 23430
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: