


OIL ANALYSIS REPORT

S-460 [7319]

Machine Id

KAESER 1031 - LOMONT MOLDING

Compressor





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Moor

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		0ct2009 1	Mar2017 Apr2018 Apr20	19 Apr2020 Oct2021 Sep2022	Nov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06015224	UCH05670494	UCH05394638
Sample Date		Client Info		22 Nov 2023	29 Sep 2022	28 Oct 2021
Machine Age	hrs	Client Info		98968	92396	86350
Oil Age	hrs	Client Info		6572	6047	6977
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	4	6	14
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	<1
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	0	0	0
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		9	6	17
Zinc	ppm	ASTM D5185m		17	8	0
Sulfur	ppm	ASTM D5185m		15414	18823	14499
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	1
Sodium	ppm	ASTM D5185m		1	3	0
Potassium	ppm	ASTM D5185m	>20	0	0	0
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
A -tal Niconala - o (ANI)		4 OTM DOC 45	0.4	0.44	0.47	0.400

Acid Number (AN)

mg KOH/g ASTM D8045 0.4


0.47

0.44

0.462




OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.0	43.8	41.4
SAMPLE IMAGES		method	limit/base	current	history1	history2


Color

Bottom













Laboratory Sample No. Lab Number

Unique Number

: UCH06015224 : 06015224 : 10754368

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed

: 22 Nov 2023 : 26 Nov 2023 Diagnostician : Don Baldridge **DELTA INDUSTRIES - CEDAR RAPIDS**

6540 4TH ST SW CEDAR RAPIDS, IA US 52404

Contact: MICHAEL FERRIS wearcheck@deltaind.net

T: (319)862-2500 F: (319)862-2501

Test Package : IND 2 Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCDELCED [WUSCAR] 06015224 (Generated: 11/26/2023 10:12:38) Rev: 1

Contact/Location: MICHAEL FERRIS - UCDELCED