




PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id
MOGGPB-1 (S/N 16-119)
 Component
Hydraulic Power Pack
 Fluid
MOBIL DTE 25 (335 GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. (Customer Sample Comment: Viscosity index please)

PROBLEMATIC TEST RESULTS

Sample Status		ATTENTION	ABNORMAL	---
Particles >4µm	ASTM D7647 >320	▲ 590	▲ 1362	---
Oil Cleanliness	ISO 4406 (c) >15/13/10	▲ 16/13/10	▲ 18/15/10	---

Customer Id: WESCONSC
 Sample No.: WC0782723
 Lab Number: 06015739
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

03 Apr 2023 Diag: Angela Borella

ISO



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
MOGGPB-1 (S/N 16-119)

Component
Hydraulic Power Pack

Fluid
MOBIL DTE 25 (335 GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. (Customer Sample Comment: Viscosity index please)

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0782723	WC0782729	---
Sample Date	Client Info		18 Nov 2023	03 Apr 2023	---
Machine Age	hrs	Client Info	23692	23692	---
Oil Age	hrs	Client Info	200	3400	---
Oil Changed	Client Info		Changed	Filtered	---
Sample Status			ATTENTION	ABNORMAL	---

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.05	NEG	NEG	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	0	0	---
Chromium	ppm	ASTM D5185m >20	0	0	---
Nickel	ppm	ASTM D5185m >20	0	0	---
Titanium	ppm	ASTM D5185m	0	0	---
Silver	ppm	ASTM D5185m	0	0	---
Aluminum	ppm	ASTM D5185m >20	0	1	---
Lead	ppm	ASTM D5185m >20	0	0	---
Copper	ppm	ASTM D5185m >20	4	14	---
Tin	ppm	ASTM D5185m >20	0	0	---
Vanadium	ppm	ASTM D5185m	<1	0	---
Cadmium	ppm	ASTM D5185m	0	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	---
Barium	ppm	ASTM D5185m	0	0	---
Molybdenum	ppm	ASTM D5185m	0	0	---
Manganese	ppm	ASTM D5185m	0	<1	---
Magnesium	ppm	ASTM D5185m	0	2	---
Calcium	ppm	ASTM D5185m	61	59	---
Phosphorus	ppm	ASTM D5185m	312	339	---
Zinc	ppm	ASTM D5185m	517	500	---
Sulfur	ppm	ASTM D5185m	692	575	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<1	0	---
Sodium	ppm	ASTM D5185m	<1	0	---
Potassium	ppm	ASTM D5185m >20	0	0	---






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>320	▲ 590	▲ 1362	---
Particles >6µm	ASTM D7647	>80	76	▲ 305	---
Particles >14µm	ASTM D7647	>10	7	10	---
Particles >21µm	ASTM D7647	>3	3	1	---
Particles >38µm	ASTM D7647	>3	0	0	---
Particles >71µm	ASTM D7647	>3	0	0	---
Oil Cleanliness	ISO 4406 (c)	>15/13/10	▲ 16/13/10	▲ 18/15/10	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.45	0.35	---

OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	44.2	45.1	---
Visc @ 100°C	cSt	ASTM D445	6.65	7	---
Viscosity Index (VI)	Scale	ASTM D2270	98	112	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0782723 **Received** : 22 Nov 2023
Lab Number : 06015739 **Diagnosed** : 30 Nov 2023
Unique Number : 10754883 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KV100, VI)

WEST SIDE SOLUTIONS
 4506 HWY 90
 CONWAY, SC
 US 29526-9631
 Contact: KEN ANDRE
 westsidesolutionsus@gmail.com
 T: (216)577-5014
 F:

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)