




# PROBLEM SUMMARY

Area  
**HOTLINE/120 MILL**  
 Machine Id  
**120 TRIMMER 1415-003-0020**  
 Component  
**Gearbox**  
 Fluid  
**PETRO CANADA ENDURATEX EP 220 (700 GAL)**

Sample Rating Trend




## VISCOSITY




### COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Viscosity @ 40°C



### RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

### PROBLEMATIC TEST RESULTS

Sample Status	ASTM D7647	ASTM D7647	ABNORMAL	---	SEVERE
Particles >4µm	ASTM D7647	>20000	▲ 198519	---	▲ 40610
Particles >6µm	ASTM D7647	>5000	▲ 70466	---	▲ 22123
Particles >14µm	ASTM D7647	>640	▲ 1475	---	▲ 3765
Particles >21µm	ASTM D7647	>160	▲ 170	---	▲ 1268
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 25/23/18	---	▲ 23/22/19
Visc @ 40°C	cSt	ASTM D445 220	▲ 97.6	133	▲ 135

Customer Id: CONMUSAL  
 Sample No.: KFS0005193  
 Lab Number: 06015768  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.

## HISTORICAL DIAGNOSIS

10 Nov 2023 Diag:

UNKNOWN



view report



29 Sep 2023 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a high amount of particulates present in the oil. There is a high concentration of water present in the oil. The oil viscosity is lower than normal. Confirm oil type. The AN level is acceptable for this fluid.

view report



24 Apr 2023 Diag: Doug Bogart

WATER



We advise that you check for the source of water entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. The aluminum level is abnormal. Appearance is milky. There is a high amount of visible silt present in the sample. There is a moderate concentration of water present in the oil. The oil viscosity is lower than normal. Confirm oil type. The AN level is acceptable for this fluid.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



## VISCOSITY



Area  
**HOTLINE/120 MILL**  
Machine Id  
**120 TRIMMER 1415-003-0020**  
Component  
**Gearbox**  
Fluid  
**PETRO CANADA ENDURATEX EP 220 (700 GAL)**

### DIAGNOSIS

#### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

Viscosity of sample indicates oil is within ISO 100 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.

### SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KFS0005193</b>	KFS0004819	KFS0004888
Sample Date	Client Info	<b>20 Nov 2023</b>	10 Nov 2023	29 Sep 2023
Machine Age	hrs	<b>0</b>	0	0
Oil Age	hrs	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	---	SEVERE

### CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.2	<b>NEG</b>	NEG	NEG

### WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >200	<b>11</b>	13	12
Chromium	ppm	ASTM D5185m >15	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185m >15	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>9</b>	▲ 32	24
Lead	ppm	ASTM D5185m >100	<b>0</b>	1	0
Copper	ppm	ASTM D5185m >200	<b>&lt;1</b>	1	<1
Tin	ppm	ASTM D5185m >25	<b>0</b>	0	<1
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Cadmium	ppm	ASTM D5185m	<b>0</b>	2	<1

### ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 60	<b>0</b>	0	0
Barium	ppm	ASTM D5185m 0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m 0	<b>&lt;1</b>	0	<1
Magnesium	ppm	ASTM D5185m 0	<b>0</b>	2	1
Calcium	ppm	ASTM D5185m 0	<b>13</b>	23	18
Phosphorus	ppm	ASTM D5185m 270	<b>288</b>	312	276
Zinc	ppm	ASTM D5185m 0	<b>401</b>	▲ 381	372
Sulfur	ppm	ASTM D5185m 11200	<b>788</b>	▲ 808	890

### CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	<b>&lt;1</b>	0	1
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	0	5
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	2	<1


### FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	<b>▲ 198519</b>	---	▲ 40610
Particles >6µm	ASTM D7647 >5000	<b>▲ 70466</b>	---	▲ 22123
Particles >14µm	ASTM D7647 >640	<b>▲ 1475</b>	---	▲ 3765
Particles >21µm	ASTM D7647 >160	<b>▲ 170</b>	---	▲ 1268
Particles >38µm	ASTM D7647 >40	<b>1</b>	---	▲ 196
Particles >71µm	ASTM D7647 >10	<b>0</b>	---	▲ 20
Oil Cleanliness	ISO 4406 (c) >21/19/16	<b>▲ 25/23/18</b>	---	▲ 23/22/19


### FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.40	<b>0.46</b>	0.65	0.70


### ▲ Particle Trend




### ▲ Particle Trend



### ▲ Viscosity @ 40°C




### Acid Number



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	0.2% <span style="color:red">◆</span> 0.2%
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 220	▲ 97.6	133	▲ 135

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### ▲ Viscosity @ 40°C



#### ▲ Particle Count



#### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KFS0005193 **Received** : 22 Nov 2023  
**Lab Number** : 06015768 **Diagnosed** : 30 Nov 2023  
**Unique Number** : 10754912 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**CONSTELLIUM**  
 4805 SECOND STREET  
 MUSCLE SHOALS, AL  
 US 35661  
 Contact: Joel Even  
 joel.even@constellium.com  
 T: (256)740-7490  
 F: