




PROBLEM SUMMARY


Area
HOTLINE/120 MILL
 Machine Id
120 SCREWDOWN LUBE RESV 1415-014-0160
 Component
Gearbox
 Fluid
CITGO COMPOUND EP 320 (3000 GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	---	ABNORMAL
Particles >4µm	ASTM D7647	>20000	▲ 200858	● 168165	▲ 234626
Particles >6µm	ASTM D7647	>5000	▲ 79859	● 69647	▲ 151999
Particles >14µm	ASTM D7647	>640	▲ 2194	▲ 2371	▲ 9491
Particles >21µm	ASTM D7647	>160	▲ 212	▲ 280	▲ 964
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 25/23/18	● 25/23/18	▲ 25/24/20

Customer Id: CONMUSAL
 Sample No.: KFS0005201
 Lab Number: 06015770
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.

HISTORICAL DIAGNOSIS

10 Nov 2023 Diag:

UNKNOWN



view report



19 Jul 2023 Diag: Angela Borella

WEAR



Check seals and/or filters for points of contaminant entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



23 Jun 2023 Diag: Angela Borella

WEAR



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
HOTLINE/120 MILL
 Machine Id
120 SCREWDOWN LUBE RESV 1415-014-0160
 Component
Gearbox
 Fluid
CITGO COMPOUND EP 320 (3000 GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KFS0005201	KFS0004923	KFS0003799
Sample Date	Client Info	20 Nov 2023	10 Nov 2023	19 Jul 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	---	ABNORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.2	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >200	12	12	41
Chromium	ppm	ASTM D5185m >15	0	0	<1
Nickel	ppm	ASTM D5185m >15	0	0	<1
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	7	7	▲ 30
Lead	ppm	ASTM D5185m >100	2	3	2
Copper	ppm	ASTM D5185m >200	2	<1	7
Tin	ppm	ASTM D5185m >25	0	0	<1
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	1	<1	31
Barium	ppm	ASTM D5185m	0	0	2
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	0	<1
Magnesium	ppm	ASTM D5185m	0	3	6
Calcium	ppm	ASTM D5185m	70	33	598
Phosphorus	ppm	ASTM D5185m	107	129	108
Zinc	ppm	ASTM D5185m	0	12	4
Sulfur	ppm	ASTM D5185m	5398	5288	4887

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	<1	<1	2
Sodium	ppm	ASTM D5185m	1	1	6
Potassium	ppm	ASTM D5185m >20	2	2	3


FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	▲ 200858	● 168165	▲ 234626
Particles >6µm	ASTM D7647 >5000	▲ 79859	● 69647	▲ 151999
Particles >14µm	ASTM D7647 >640	▲ 2194	▲ 2371	▲ 9491
Particles >21µm	ASTM D7647 >160	▲ 212	▲ 280	▲ 964
Particles >38µm	ASTM D7647 >40	2	4	8
Particles >71µm	ASTM D7647 >10	0	0	2
Oil Cleanliness	ISO 4406 (c) >21/19/16	▲ 25/23/18	● 25/23/18	▲ 25/24/20


FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.22	0.31	0.27


▲ Particle Trend




▲ Particle Trend



Acid Number




Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	314	350	374

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KFS0005201 **Received** : 22 Nov 2023
Lab Number : 06015770 **Diagnosed** : 27 Nov 2023
Unique Number : 10754914 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

CONSTELLIUM
 4805 SECOND STREET
 MUSCLE SHOALS, AL
 US 35661
 Contact: Joel Even
 joel.even@constellium.com
 T: (256)740-7490
 F: