




Machine Id B-829B

Component Blower Fluid NOT GIVEN (--- GAL)

COMPONENT CONDITION SUMMARY







RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. Please specify the brand and viscosity of the oil on your next sample.

PROBLEMATIC TEST RESULTS

THOBELMATIO TEOTHEODETO								
Sample Status				ABNORMAL	ABNORMAL			
Silicon	ppm	ASTM D5185m	>15	<u> </u>	<1			
Particles >4µm		ASTM D7647	>2500	<u> </u>				
Particles >6µm		ASTM D7647	>640	<u> </u>				
Particles >14µm		ASTM D7647	>80	<u> </u>				
Particles >21µm		ASTM D7647	>20	🔺 165				
Particles >38µm		ASTM D7647	>4	<u> </u>				
Oil Cleanliness		ISO 4406 (c)	>18/16/13	<u> </u>				

Customer Id: POEHAN Sample No.: USP244922 Lab Number: 06016436 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED A	COMMENDED ACTIONS						
Action	Status	Date	Done By	Description			
Change Filter			?	We recommend you service the filters on this component if applicable.			
Information Required			?	Please specify the brand, type, and viscosity of the oil on your next sample.			

HISTORICAL DIAGNOSIS



05 Jun 2023 Diag: Doug Bogart

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The oil viscosity is lower than normal. Confirmed. The AN level is acceptable for this fluid.





OIL ANALYSIS REPORT

Sample Rating Trend

DIRT

Machine Id B-829B Component Blower

Fluid NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. Please specify the brand and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP244922	USP243070	
Sample Date		Client Info		10 Nov 2023	05 Jun 2023	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	15	0	
Chromium	ppm	ASTM D5185m	>20	<1	0	
Nickel	ppm	ASTM D5185m	>20	<1	0	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>20	2	0	
Lead	ppm	ASTM D5185m	>20	0	0	
Copper			>20	۰ <1	<1	
Tin	ppm	ASTM D5185m	>20	<1 0	0	
Vanadium	ppm		>20	0	0	
Cadmium	ppm	ASTM D5185m ASTM D5185m				
	ppm	ASTM DS185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m		<1	2	
Calcium	ppm	ASTM D5185m		1	0	
Phosphorus	ppm	ASTM D5185m		394	510	
Zinc	ppm	ASTM D5185m		0	0	
Sulfur	ppm	ASTM D5185m		46	0	
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<u> </u>	<1	
Sodium	ppm	ASTM D5185m		1	<1	
Potassium	ppm	ASTM D5185m	>20	<1	1	
Water	%	ASTM D6304		0.011	0.004	
ppm Water	ppm	ASTM D6304		110	49.8	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	A 188666		
Particles >6µm		ASTM D7647	>640	A 39126		
Particles >14µm		ASTM D7647	>80	<u> </u>		
Particles >21µm		ASTM D7647	>20	🔺 165		
Particles >38µm		ASTM D7647	>4	<u> </u>		
Particles >71µm		ASTM D7647	>3	1		
Oil Cleanliness		ISO 4406 (c)	>18/16/13	4 25/22/16		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.58	0.75	



명 0.20

0.10 0.00

1200

100

80

600

200

Abnorma

Water 400


Water (KF)


OIL ANALYSIS REPORT

method

limit/base

current





Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Laboratory

Sample No.

Lab Number

Unique Number

Test Package

Contact/Location: Service Manager - POEHAN

F:

history2