




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
E-2 (S/N 1144675)

Component
Biogas Engine

Fluid
MAHLER Q8 Mahler G8 SAE 40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0852851	WC0852847	WC0852845
Sample Date	Client Info			20 Nov 2023	13 Nov 2023	06 Nov 2023
Machine Age	hrs	Client Info		10079	9911	9753
Oil Age	hrs	Client Info		3340	3172	3014
Oil Changed	Client Info			Not Changed	Not Changed	Not Changed
Sample Status				NORMAL	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>4.0		<1.0	<1.0	<1.0
Water	WC Method	>0.1		NEG	NEG	NEG
Glycol	WC Method			NEG	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>45	1	<1	4
Chromium	ppm	ASTM D5185m	>2	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	<1	0	0
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>10	5	4	6
Lead	ppm	ASTM D5185m	>5	2	<1	2
Copper	ppm	ASTM D5185m	>14	0	<1	<1
Tin	ppm	ASTM D5185m	>13	5	5	6
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<1	0	1
Barium	ppm	ASTM D5185m		0	0	7
Molybdenum	ppm	ASTM D5185m		1	<1	3
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m		15	15	17
Calcium	ppm	ASTM D5185m		2480	2483	3094
Phosphorus	ppm	ASTM D5185m		494	478	655
Zinc	ppm	ASTM D5185m		560	599	729
Sulfur	ppm	ASTM D5185m		2957	3076	4472




CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>200	65	58	74
Sodium	ppm	ASTM D5185m		7	5	7
Potassium	ppm	ASTM D5185m	>20	2	3	4

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0.1	0.1	0
Nitration	Abs/cm	*ASTM D7624	>20	8.7	8.4	8.2
Sulfation	Abs/.1mm	*ASTM D7415	>30	21.4	20.9	20.5

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	16.9	16.3	16.0
Acid Number (AN)	mg KOH/g	ASTM D8045		1.25	1.44	0.88
Base Number (BN)	mg KOH/g	ASTM D2896	8.0	6.55	5.77	6.02











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	13.2	14.1	14.1	13.9

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0852851 **Received** : 24 Nov 2023
Lab Number : 06016644 **Diagnosed** : 28 Nov 2023
Unique Number : 10755788 **Diagnostician** : Sean Felton
Test Package : MOB 2

OAK GROVE GA
 967 CARL-BETHLEHEM RD
 WINDER, GA
 US 30680
 Contact: MATT DICKENS

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: