




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
INK4_U2120 INK4_U2120_SS2120

Component
Non-Drive End Seal Pot

Fluid
ROYAL PURPLE BARRIER FLUID FDA22 (--- GAL)

DIAGNOSIS

Recommendation

We recommend an early resample to monitor this condition.

Contamination

Insufficient sample was received to conduct all the routine laboratory tests. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		RP0034164	RP0034076	RP0026178
Sample Date	Client Info		15 Nov 2023	25 Sep 2023	14 Jun 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	---	0	---
Chromium	ppm	ASTM D5185m >20	---	0	---
Nickel	ppm	ASTM D5185m >20	---	0	---
Titanium	ppm	ASTM D5185m	---	0	---
Silver	ppm	ASTM D5185m	---	0	---
Aluminum	ppm	ASTM D5185m >20	---	0	---
Lead	ppm	ASTM D5185m >20	---	0	---
Copper	ppm	ASTM D5185m >20	---	0	---
Tin	ppm	ASTM D5185m >20	---	0	---
Vanadium	ppm	ASTM D5185m	---	0	---
Cadmium	ppm	ASTM D5185m	---	0	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	---	0	---
Barium	ppm	ASTM D5185m	---	0	---
Molybdenum	ppm	ASTM D5185m	---	0	---
Manganese	ppm	ASTM D5185m	---	0	---
Magnesium	ppm	ASTM D5185m	---	4	---
Calcium	ppm	ASTM D5185m	---	0	---
Phosphorus	ppm	ASTM D5185m	---	22	---
Zinc	ppm	ASTM D5185m	---	0	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	---	<1	---
Sodium	ppm	ASTM D5185m	---	1	---
Potassium	ppm	ASTM D5185m >20	---	0	---
Water	%	ASTM D6304 >0.05	0.007	0.006	0.001
ppm Water	ppm	ASTM D6304 >500	75	61.7	11.3




FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.047	0.044	0.085

VISUAL


	method	limit/base	current	history1	history2
White Metal	scalar	*Visual NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual NONE	NONE	NONE	NONE
Silt	scalar	*Visual NONE	NONE	NONE	NONE
Debris	scalar	*Visual NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual NONE	NONE	NONE	NONE
Appearance	scalar	*Visual NORML	NORML	NORML	NORML
Odor	scalar	*Visual NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual >0.05	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	---	---

OIL ANALYSIS REPORT







FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	5.2	---	5.71	5.92

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0034164 **Received** : 24 Nov 2023
Lab Number : 06016952 **Diagnosed** : 28 Nov 2023
Unique Number : 10756096 **Diagnostician** : Jonathan Hester
Test Package : IND 2

ENERGY TRANSFER - INKSTER
 7155 INKSTER ROAD
 TAYOR, MI
 US 48180
 Contact: NATHAN HOLMES
 nathan.holmes@energytransfer.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: