

# **PROBLEM SUMMARY**

# KAESER SFC 755 3433120 (S/N 1035)

Compressor

# KAESER SIGMA (OEM) S-460 (--- GAL)

## COMPONENT CONDITION SUMMARY



#### RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status			ATTENTION	ABNORMAL	ABNORMAL		
Particles >14µm	ASTM D7647	>80	<u> </u>	<u> </u>			
Particles >21µm	ASTM D7647	>20	<b>A</b> 35	<b>4</b> 36			
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u> </u>	🔺 21/19/15			

Customer Id: ACCPAT Sample No.: KC123029 Lab Number: 06017393 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

*To change component or sample information:* Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



#### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

#### **HISTORICAL DIAGNOSIS**

#### 03 Nov 2022 Diag: Don Baldridge

#### Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

#### 26 Jan 2022 Diag: Don Baldridge



We advise that you stop the unit and follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid.

#### 14 May 2021 Diag: Don Baldridge

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





view report

view report



Report Id: ACCPAT [WUSCAR] 06017393 (Generated: 11/29/2023 15:37:02) Rev: 1



# **OIL ANALYSIS REPORT**

# KAESER SFC 755 3433120 (S/N 1035)

**Compressor** Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC123029	KC106189	KC96939
Sample Date		Client Info		14 Jul 2023	03 Nov 2022	26 Jan 2022
Machine Age	hrs	Client Info		100779	95278	89265
Oil Age	hrs	Client Info		0	5800	6154
Oil Changed		Client Info		N/A	Changed	Not Change
Sample Status				ATTENTION	ABNORMAI	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	2
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	6	12	17
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
			11 11 11			
ADDITIVE5		method	limit/base	current	history i	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	1	11	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	90	20	24	14
Calcium	ppm	ASTM D5185m	2	0	0	<1
Phosphorus	ppm	ASTM D5185m		0	4	7
Zinc	ppm	ASTM D5185m		10	8	13
CONTAMINANTS		method	limit/base	current	history1	history2
Silioon	nnm	ACTM DE105m	. 25	0	-1	-1
Shicon	ppm	ASTM D5105III	>20	0	< 1	< 1
Botaccium	ppm	ASTM D5185m	> 20	0	2	-1
Water	ррш •/		>20	1	0.017	< 1
Walei	70	ASTM DC204	>0.05	109	179.0	0.340
ppm water	ррпі	ASTIVI D0304	>500	190	176.0	3460
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3840	11246	
Particles >6µm		ASTM D7647	>1300	934	<b>A</b> 2856	
Particles >14µm		ASTM D7647	>80	<b>113</b>	<b>2</b> 43	
Particles >21µm		ASTM D7647	>20	<b>A</b> 35	<b>A</b> 36	
Particles >38µm		ASTM D7647	>4	1	1	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>19/17/14</b>	<b>2</b> 1/19/15	
		mothed	limit/baca	ourroot	historyd	history
I LUID DEGRADA		method	-infit/base	current	TIISTOLY I	nistory2
Acid Number (AN)	ma KOH/a	ASTM D8045	() 4	037	0.30	0.37



# **OIL ANALYSIS REPORT**







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	LIGHT	A MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	<b>1</b> .0
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.6	45.3	44.5
SAMPLE IMAGES		method	limit/base	current	history1	history2





Bottom



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)