




# PROBLEM SUMMARY

Sample Rating Trend



## VIS DEBRIS



Machine Id  
**KAESER AS 30 6106823 (S/N 1040)**  
 Component  
**Compressor**  
 Fluid  
**TAC 46 (--- GAL)**

### COMPONENT CONDITION SUMMARY

No relevant graphs to display

### RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

### PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ATTENTION	ABNORMAL
Debris	scalar	*Visual	NONE	▲ MODER	NONE	NONE

Customer Id: GULPHI  
 Sample No.: KC121821  
 Lab Number: 06017407  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

## HISTORICAL DIAGNOSIS

### 04 Nov 2021 Diag: Don Baldrige

ISO



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 12 May 2020 Diag: Don Baldrige

WEAR



Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. The copper level is abnormal. All other component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



### 11 Nov 2019 Diag: Jonathan Hester

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Machine Id  
**KAESER AS 30 6106823 (S/N 1040)**

Component  
**Compressor**  
Fluid  
**TAC 46 (--- GAL)**



## DIAGNOSIS

### ▲ Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

### Wear

All component wear rates are normal.

### ▲ Contamination

Moderate concentration of visible dirt/debris present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KC121821</b>	KC98942	KC72929
Sample Date	Client Info	<b>20 Nov 2023</b>	04 Nov 2021	12 May 2020
Machine Age	hrs	<b>29333</b>	21656	12919
Oil Age	hrs	<b>0</b>	2671	6164
Oil Changed	Client Info	<b>N/A</b>	Not Changd	Changed
Sample Status		<b>ABNORMAL</b>	ATTENTION	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >50	<b>6</b>	0	0
Chromium	ppm ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm ASTM D5185m >3	<b>0</b>	0	0
Titanium	ppm ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm ASTM D5185m >2	<b>0</b>	0	<1
Aluminum	ppm ASTM D5185m >10	<b>7</b>	0	0
Lead	ppm ASTM D5185m >10	<b>0</b>	0	<1
Copper	ppm ASTM D5185m >50	<b>2</b>	14	▲ 100
Tin	ppm ASTM D5185m >10	<b>0</b>	0	0
Antimony	ppm ASTM D5185m	<b>---</b>	0	0
Vanadium	ppm ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	<b>0</b>	0	<1
Barium	ppm ASTM D5185m	<b>0</b>	6	<1
Molybdenum	ppm ASTM D5185m	<b>0</b>	0	0
Manganese	ppm ASTM D5185m	<b>0</b>	0	0
Magnesium	ppm ASTM D5185m	<b>0</b>	9	<1
Calcium	ppm ASTM D5185m	<b>0</b>	0	<1
Phosphorus	ppm ASTM D5185m	<b>341</b>	0	0
Zinc	ppm ASTM D5185m	<b>127</b>	0	0

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >25	<b>0</b>	0	3
Sodium	ppm ASTM D5185m	<b>3</b>	0	0
Potassium	ppm ASTM D5185m >20	<b>&lt;1</b>	0	<1
Water	% ASTM D6304 >0.05	<b>0.003</b>	0.009	0.005
ppm Water	ppm ASTM D6304 >500	<b>32</b>	94.3	52.0




## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	<b>---</b>	8347	1315
Particles >6µm	ASTM D7647 >1300	<b>---</b>	1284	597
Particles >14µm	ASTM D7647 >80	<b>---</b>	74	▲ 129
Particles >21µm	ASTM D7647 >20	<b>---</b>	▲ 30	▲ 48
Particles >38µm	ASTM D7647 >4	<b>---</b>	▲ 5	▲ 5
Particles >71µm	ASTM D7647 >3	<b>---</b>	0	0
Oil Cleanliness	ISO 4406 (c) >--/17/13	<b>---</b>	17/13	▲ 16/14

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	<b>0.25</b>	0.345	0.297


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	▲ MODER	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46.3	44.4	44.5

**SAMPLE IMAGES**



**GRAPHS**



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KC121821 **Received** : 24 Nov 2023  
**Lab Number** : 06017407 **Diagnosed** : 29 Nov 2023  
**Unique Number** : 10756551 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2

**GULBRANDSEN TECHNOLOGIES**  
 1 RIVERSIDE WAY  
 PHILLIPSBURG, NJ  
 US 08865  
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: