

PROBLEM SUMMARY


Sample Rating Trend

ISO

Machine Id KAESER AS 25T 7005367 (S/N 1375)


Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)





COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	NORMAL	NORMAL				
Particles >6µm	ASTM D7647	>1300	2668	889	555				
Particles >14µm	ASTM D7647	>80	156	32	36				
Particles >21µm	ASTM D7647	>20	44	6	8				
Oil Cleanliness	ISO 4406 (c)	>17/13	19/14	17/12	16/12				

Customer Id: ALTFRETX Sample No.: KCPA009813 Lab Number: 06025730 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

10 Oct 2022 Diag: Angela Borella

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



08 Apr 2022 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



11 Sep 2021 Diag: Don Baldridge

150



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER AS 25T 7005367 (S/N 1375)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul2020	Dec2020 Sep2021	Apr2022 Oct2022	Nov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA009813	KCP46974	KCP45245
Sample Date		Client Info		20 Nov 2023	10 Oct 2022	08 Apr 2022
Machine Age	hrs	Client Info		32739	24913	20830
Oil Age	hrs	Client Info		0	8508	0
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	5	6	2
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	7	0	39
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	90	26	28	75
Calcium	ppm	ASTM D5185m	2	0	0	4
Phosphorus	ppm	ASTM D5185m		2	17	8
Zinc	ppm	ASTM D5185m		0	0	<1
Sulfur	ppm	ASTM D5185m		18094	21249	16613
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		8	11	31
Potassium	ppm	ASTM D5185m	>20	<1	3	6
Water	%	ASTM D6304	>0.05	0.011	0.015	0.024
ppm Water	ppm	ASTM D6304	>500	115	150.7	248.5
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		10701	9457	2965
Particles >6μm		ASTM D7647		^ 2668	889	555
Particles >14μm		ASTM D7647	>80	<u> </u>	32	36
Particles >21µm		ASTM D7647	>20	44	6	8
Particles >38µm		ASTM D7647	>4	3	0	0
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>17/13	<u> </u>	17/12	16/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Contact/Location: ? ? - ALTFRETX



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: 06025730

: KCPA009813 : 10770230

Received Diagnosed

: 07 Dec 2023 Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

6120 E US HWY 290 FREDERICKSBURG, TX US 78624

Contact:

T: F: