

PROBLEM SUMMARY

Sample Rating Trend


WATER


FES HSC 1 (S/N 01197-002-1-01-01)

Refrigeration Compressor

USPI 1009-68 SC (--- GAL)

COMPONENT CONDITION SUMMARY





RECOMMENDATION

Resample at the next service interval to monitor.

| PROBLEMATIC TEST RESULTS | | | | | | | | |
|--------------------------|-----|--------------|-----------|-----------------|----------------|----------|--|--|
| Sample Status | | | | ATTENTION | ABNORMAL | ABNORMAL | | |
| Water | % | ASTM D6304 | >0.01 | △ 0.030 | △ 0.054 | ▲ 0.020 | | |
| ppm Water | ppm | ASTM D6304 | >100 | 305 | ▲ 548.3 | ▲ 201.3 | | |
| Particles >6µm | | ASTM D7647 | >2500 | <u> </u> | 2337 | 1236 | | |
| Oil Cleanliness | | ISO 4406 (c) | >20/18/15 | 20/19/14 | 21/18/12 | 20/17/10 | | |

Customer Id: TYSCON Sample No.: USP0003957 Lab Number: 06025751 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

07 Sep 2023 Diag: Doug Bogart

WATER



Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 6 microns in size) present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



13 Jun 2023 Diag: Doug Bogart

WATER



We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. All component wear rates are normal. Free water present. There is a trace of moisture present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



01 Apr 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Status

Sample Rating Trend



ATTENTION ABNORMAL ABNORMAL

FES HSC 1 (S/N 01197-002-1

Refrigeration Compressor

USPI 1009-68 SC (--- GAL)

DIAGNOSIS Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| ?-1-01-01) | 2g/2017 May, | 2018 Ju2019 Apr2020 Feb | 2021 Nov2021 Jul2022 | Jun 2023 | |
|-----------------|--------------|-------------------------|----------------------|-------------|-------------|
| SAMPLE INFORMAT | ION method | limit/base | current | history1 | history2 |
| Sample Number | Client Info | U | SP0003957 | USP248533 | USP248532 |
| Sample Date | Client Info | 2 | 8 Nov 2023 | 07 Sep 2023 | 13 Jun 2023 |
| Machine Age hrs | Client Info | 8 | 388 | 8389 | 8389 |
| Oil Age hrs | Client Info | 0 | | 0 | 0 |
| Oil Changed | Client Info | N | I/ A | Not Changd | Not Changd |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|-------------|-------------|---------|----------|----------|
| Iron | ppm | ASTM D5185m | >8 | 0 | <1 | 1 |
| Chromium | ppm | ASTM D5185m | >2 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Lead | ppm | ASTM D5185m | >2 | 0 | 0 | <1 |
| Copper | ppm | ASTM D5185m | >8 | 0 | 0 | 0 |
| Tin | ppm | ASTM D5185m | >4 | 0 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| ADDITIVES | | mothod | limit/bases | avvant | biotomid | history |

| ADDITIVES | | memod | IIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII | Current | HISTORY | HISTORYZ |
|------------|-----|-------------|---|---------|---------|----------|
| Boron | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | <1 | 0 | <1 |
| Magnesium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Calcium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | | 0 | 0 | <1 |
| Zinc | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Sulfur | ppm | ASTM D5185m | 50 | 29 | 0 | 6 |

| CONTAMINANT | S | method | limit/base | current | history1 | history2 |
|-------------------|-----|-------------|------------|----------------|----------------|----------------|
| Silicon | ppm | ASTM D5185m | >15 | 0 | <1 | 0 |
| Sodium | ppm | ASTM D5185m | | <1 | <1 | 0 |
| Potassium | ppm | ASTM D5185m | >20 | 0 | 0 | <1 |
| Water | % | ASTM D6304 | >0.01 | △ 0.030 | △ 0.054 | △ 0.020 |
| ppm Water | ppm | ASTM D6304 | >100 | ▲ 305 | △ 548.3 | △ 201.3 |
| FLUID CLEANLINESS | | method | limit/base | current | history1 | history2 |
| | | | | | | |

| FLUID CLEANLINESS | method | limit/base | current | history1 | history2 |
|-------------------|--------------|------------|-----------------|-------------------|----------|
| Particles >4µm | ASTM D7647 | >10000 | 9822 | <u> </u> | 7453 |
| Particles >6μm | ASTM D7647 | >2500 | <u> </u> | 2337 | 1236 |
| Particles >14μm | ASTM D7647 | >320 | 135 | 39 | 8 |
| Particles >21µm | ASTM D7647 | >80 | 22 | 5 | 1 |
| Particles >38μm | ASTM D7647 | >20 | 0 | 1 | 0 |
| Particles >71µm | ASTM D7647 | >4 | 0 | 1 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >20/18/15 | <u>20/19/14</u> | △ 21/18/12 | 20/17/10 |

FLUID DEGRADATION method limit/base current history1 history2 0.013 0.015 Acid Number (AN) mg KOH/g ASTM D974 0.005 0.015



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: USP0003957 : 06025751 : 10775542 Test Package : IND 2

: 05 Dec 2023 Received : 06 Dec 2023 Diagnosed

Diagnostician : Doug Bogart 1901 S. ST. LOUIS STREET

CONCORDIA, MO US 64020

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: