

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

NOT GIVEN IL0034371

Diesel Engine Fluid DIESEL ENGINE OIL SAE 40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) DIESEL ENGINE OIL SAE 40. Please confirm. Please specify the component make and model with your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

				Dec2023		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		IL0034371		
Sample Date		Client Info		05 Dec 2023		
Machine Age	mls	Client Info		0		
Oil Age	mls	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION	١	method	limit/base	current	history1	history2
Fuel		WC Method	>5	<1.0		
Water		WC Method	>0.2	NEG		
Glycol		WC Method		NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>100	11		
Chromium	ppm	ASTM D5185m	>20	<1		
Nickel	ppm	ASTM D5185m	>4	<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m	>3	0		
Aluminum	ppm	ASTM D5185m	>20	3		
Lead	ppm	ASTM D5185m	>40	<1		
Copper	ppm	ASTM D5185m	>330	2		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	250	0		
Barium	ppm	ASTM D5185m	10	0		
Molybdenum	ppm	ASTM D5185m	100	60		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	450	983		
Calcium	ppm	ASTM D5185m	3000	1025		
Phosphorus	ppm	ASTM D5185m	1150	1022		
Zinc	ppm	ASTM D5185m	1350	1252		
Sulfur	ppm	ASTM D5185m	4250	2859		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4		
Sodium	ppm	ASTM D5185m	>216	<1		
Potassium	ppm	ASTM D5185m	>20	3		
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	>3	0.4		
Nitration	Abs/cm	*ASTM D7624	>20	8.2		
Sulfation	Abs/.1mm	*ASTM D7415	>30	21.3		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	20.0		
Base Number (BN)	mg KOH/g	ASTM D2896	8.5	8.3		



OIL ANALYSIS REPORT





	VISUAL		method				history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
/23	Appearance	scalar	*Visual	NORML	NORML		
Dec5/23	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.2	NEG		
	Free Water	scalar	*Visual	20.2	NEG		
	FLUID PROPERT		method	limit/base	current	history1	history2
	Visc @ 100°C	cSt	ASTM D445	14.4	13.1		
	GRAPHS						
	Ferrous Alloys						
_	12 iron						
	10 - nickel						
	8						
	§ 6-						
	4						
	2						
				+			
	Dec5/23			Dec5/23			
	□ Non-ferrous Meta	L					
		c					
	10 copper						
	¹⁰ T						
	10 copper						
	copper 8 6						
	8						
	10 8 6 4						
	copper 8 6						
	10 8 6 4 2 0			52			
	10 8 6 4 2 0			Dec5/23			
	10 copper lead 4 2 0 C C C C C C C C C C C C C			Dec5/23			
	10 8 6 4 2 0			Dec2533	Base Number		
	Viscosity @ 100°C			14.0			
	Viscosity @ 100°C			14.0	T		
	Viscosity @ 100°C			14.0	T		
	Viscosity @ 100°C			14.0	Abnormal Base		
	Viscosity @ 100°C			14.0	Abnormal Base		
	Viscosity @ 100°C			14.0 12.0 (PHO 10.0 8.0 8.0 9 8.0	Abnormal Base		
	Viscosity @ 100°C			14.0	Abnormal Base		
	Viscosity @ 100°C			14.0 12.0 14.0 14.0 14.0 14.0 14.0 14.0 14.0 14	Abnormal Base Abnormal		
	Viscosity @ 100°C			14.0 12.0 (Ph10.0 Line 8.0 4.0 2.0	Abnormal Base		

: 07 Dec 2023



Test Package : FLEET Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. linleym@rushtruckcenters.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnosed

Diagnostician : Wes Davis

Lab Number

Unique Number : 10775813

: 06026022

Contact/Location: MIKE LINLEY - IDECHIIL

CHICAGO, IL

Contact: MIKE LINLEY

T: (708)496-7500

F: (708)496-8818

US 60638