




PROBLEM SUMMARY

Sample Rating Trend




DEGRADATION




Area
VACUUM PUMP
 Machine Id
B68189 - BUSCH ROTARY VANE
 Component
Vacuum Pump
 Fluid
BUSCH R530S (--- GAL)

COMPONENT CONDITION SUMMARY

Acid Number



Particle Trend



RECOMMENDATION

We advise that you check for a possible overheat condition. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

| Sample Status | | SEVERE | ABNORMAL | SEVERE |
|------------------|------------------------|------------|------------|----------|
| Particles >4µm | ASTM D7647 >5000 | ▲ 30099 | ▲ 45925 | 3349 |
| Particles >6µm | ASTM D7647 >1300 | ▲ 5574 | ▲ 7913 | 814 |
| Particles >14µm | ASTM D7647 >160 | ▲ 281 | 144 | 71 |
| Particles >21µm | ASTM D7647 >40 | ▲ 74 | 17 | 16 |
| Oil Cleanliness | ISO 4406 (c) >19/17/14 | ▲ 22/20/15 | ▲ 23/20/14 | 19/17/13 |
| Acid Number (AN) | mg KOH/g ASTM D8045 | ● 2.34 | 0.076 | ● 2.20 |

Customer Id: PAPOMA
 Sample No.: WC0872417
 Lab Number: 06026369
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|-----------------------|--------|------|---------|---|
| Change Fluid | --- | --- | ? | We recommend that you drain the oil from the component if this has not already been done. |
| Resample | --- | --- | ? | We recommend an early resample to monitor this condition. |
| Check For Overheating | --- | --- | ? | We advise that you check for a possible overheat condition. |

HISTORICAL DIAGNOSIS

26 May 2023 Diag: Don Baldrige

CONTAMINANT



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Appearance is layered. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



23 Feb 2023 Diag: Don Baldrige

DEGRADATION



We advise that you check for a possible overheat condition. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is above the recommended limit.

view report



23 Nov 2022 Diag: Don Baldrige

DEGRADATION



We advise that you check for a possible overheat condition. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is above the recommended limit.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Area
VACUUM PUMP
Machine Id
B68189 - BUSCH ROTARY VANE
Component
Vacuum Pump
Fluid
BUSCH R530S (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check for a possible overheat condition. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is above the recommended limit.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | WC0872417 | WC0781480 | WC0691452 |
| Sample Date | Client Info | | 24 Nov 2023 | 26 May 2023 | 23 Feb 2023 |
| Machine Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Changed | Client Info | | Not Changed | Not Changd | Not Changed |
| Sample Status | | | SEVERE | ABNORMAL | SEVERE |

CONTAMINATION

| | method | limit/base | current | history1 | history2 |
|-------|-----------|------------|------------|----------|----------|
| Water | WC Method | >.1 | NEG | NEG | NEG |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|-----------------|----------|----------|----------|
| Iron | ppm | ASTM D5185m >20 | 0 | <1 | 1 |
| Chromium | ppm | ASTM D5185m >20 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m >20 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m >20 | 0 | <1 | <1 |
| Lead | ppm | ASTM D5185m >20 | 0 | 0 | 0 |
| Copper | ppm | ASTM D5185m >20 | 0 | 0 | 0 |
| Tin | ppm | ASTM D5185m >20 | 0 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|-------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | 1 | 0 | <1 |
| Barium | ppm | ASTM D5185m | 0 | 2 | 0 |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | <1 | <1 | 0 |
| Magnesium | ppm | ASTM D5185m | 0 | 3 | 0 |
| Calcium | ppm | ASTM D5185m | 2 | 4 | 6 |
| Phosphorus | ppm | ASTM D5185m | 2 | 6 | 2 |
| Zinc | ppm | ASTM D5185m | 0 | 16 | 2 |
| Sulfur | ppm | ASTM D5185m | 42 | 43 | 48 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|-----------------|----------|----------|----------|
| Silicon | ppm | ASTM D5185m >15 | 8 | 9 | 7 |
| Sodium | ppm | ASTM D5185m | 7 | <1 | 8 |
| Potassium | ppm | ASTM D5185m >20 | 0 | <1 | 0 |

FLUID CLEANLINESS

| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|-------------------|------------|----------|
| Particles >4µm | ASTM D7647 | >5000 | ▲ 30099 | ▲ 45925 | 3349 |
| Particles >6µm | ASTM D7647 | >1300 | ▲ 5574 | ▲ 7913 | 814 |
| Particles >14µm | ASTM D7647 | >160 | ▲ 281 | 144 | 71 |
| Particles >21µm | ASTM D7647 | >40 | ▲ 74 | 17 | 16 |
| Particles >38µm | ASTM D7647 | >10 | 4 | 3 | 2 |
| Particles >71µm | ASTM D7647 | >3 | 1 | 2 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >19/17/14 | ▲ 22/20/15 | ▲ 23/20/14 | 19/17/13 |


FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 2.34 | 0.076 | 2.20 |




OIL ANALYSIS REPORT


▲ Particle Trend




▲ Particle Count



▲ Particle Trend



Viscosity @ 40°C




| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | ▲ LAYRD | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >.1 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 95.0 | 132 | 107 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|


Color




Bottom

GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



● Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0872417 Received : 06 Dec 2023
 Lab Number : 06026369 Diagnosed : 07 Dec 2023
 Unique Number : 10776160 Diagnostician : Don Baldrige
 Test Package : IND 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

PAPILLION FOODS
 10808 S 132ND ST
 OMAHA, NE
 US 68138
 Contact: NEIL ARIANO
 njariano@hormel.com

T:
F: