




# OIL ANALYSIS REPORT

## Sample Rating Trend



**INSOLUBLES**



Machine Id  
**NEW CML 2**

Component  
**Hydraulic System**

Fluid  
**PHILLIPS 66 Powerflow NZ AW46 (1350 GAL)**

### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. We recommend an early resample to monitor this condition. RPVOT performed at subcontracted ISO 17025 laboratory. RPVOT measured at 390.

#### Wear

All component wear rates are normal.

#### Contamination

MPC (Membrane Patch Colorimetry) test indicates a moderate concentration of varnish present. The water content is negligible. The amount and size of particulates present in the system are acceptable.

#### Fluid Condition

Linear Sweep Voltammetry (RULER – ASTM D6971) testing indicates normal levels of anti-oxidants present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0837859</b>	WCi2302203	WCi2290679
Sample Date	Client Info		<b>29 Nov 2023</b>	16 Feb 2017	07 Jun 2016
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >40	<b>0</b>	1	<1
Chromium	ppm	ASTM D5185m >4	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185m >20	<b>0</b>	<1	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >4	<b>0</b>	<1	0
Lead	ppm	ASTM D5185m >10	<b>0</b>	<1	0
Copper	ppm	ASTM D5185m >60	<b>4</b>	9	8
Tin	ppm	ASTM D5185m >4	<b>0</b>	2	<1
Antimony	ppm	ASTM D5185m	<b>---</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	1	<1
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	<1	<1
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Magnesium	ppm	ASTM D5185m	<b>0</b>	2	2
Calcium	ppm	ASTM D5185m	<b>49</b>	53	56
Phosphorus	ppm	ASTM D5185m	<b>453</b>	291	317
Zinc	ppm	ASTM D5185m	<b>575</b>	362	368
Sulfur	ppm	ASTM D5185m	<b>1142</b>	782	776

### CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >20	<b>0</b>	1	<1
Sodium	ppm	ASTM D5185m	<b>1</b>	2	<1
Potassium	ppm	ASTM D5185m >20	<b>0</b>	2	3
Water	%	ASTM D6304 >0.05	<b>0.003</b>	---	---
ppm Water	ppm	ASTM D6304 >500	<b>28</b>	---	---

### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>320</b>	104	246
Particles >6µm	ASTM D7647	>1300	<b>99</b>	48	134
Particles >14µm	ASTM D7647	>160	<b>15</b>	11	22
Particles >21µm	ASTM D7647	>40	<b>5</b>	5	7
Particles >38µm	ASTM D7647	>10	<b>1</b>	0	1
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>15/14/11</b>	14/13/11	15/14/12










# OIL ANALYSIS REPORT



FLUID DEGRADATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.22	<b>0.46</b>	0.366	0.384
Anti-Oxidant 1	%	ASTM D6971	<25	<b>64</b>	---	---
Anti-Oxidant 2	%	ASTM D6971	<25	<b>78</b>	---	---
MPC Varnish Potential	Scale	ASTM D7843	>15	<b>▲ 38</b>	---	---

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	VLITE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	46	<b>43.8</b>	45.08	45.29
Oxidation Test (RPVOT)	minutes	*ASTM D2272		<b>390</b>	---	---


SAMPLE IMAGES	method	limit/base	current	history1	history2	
Color						
Bottom						
MPC					no image	no image




**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0837859 **Received** : 06 Dec 2023  
**Lab Number** : **06026378** **Diagnosed** : 26 Dec 2023  
**Unique Number** : 10776169 **Diagnostician** : Doug Bogart  
**Test Package** : AOM 1 ( Additional Tests: KF, RPVOT )

**BALDWIN FILTERS INC**  
 4400 HIGHWAY 30 EAST  
 KEARNEY, NE  
 US 68847-0724  
 Contact: JAY FAHRENBRUCH  
 jay.fahrenbruch@parker.com  
 T:  
 F: (800)828-4453

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)



MPC (Varnish Test)



Sample Color & Clarity



*This page left intentionally blank*