


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



# Machine Id KAESER DSD 150 4488857 (S/N 1040)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Sep 2018	Apr2019 Sep2019	Nov2019 Aug2020 Dec2022	Nov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA011493	KCP45757	KCP29241
Sample Date		Client Info		28 Nov 2023	01 Dec 2022	03 Aug 2020
Machine Age	hrs	Client Info		0	64626	44813
Oil Age	hrs	Client Info		0	19795	9925
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				NORMAL	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	2	<1	5
Tin	ppm	ASTM D5185m	>10	<1	5	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	<1
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	90	0	0	1
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		2	1	0
Zinc	ppm	ASTM D5185m		0	0	<1
Sulfur	ppm	ASTM D5185m		7726	6556	10343
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	1
Sodium	ppm	ASTM D5185m		1	<1	0
Potassium	ppm	ASTM D5185m	>20	0	0	3
Water	%	ASTM D6304	>0.05	0.005	0.009	0.005
ppm Water	ppm	ASTM D6304	>500	54	90.3	52.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1165	4928	1002
Particles >6μm		ASTM D7647	>1300	347	<u></u> 1580	217
Particles >14μm		ASTM D7647	>80	32	<u> </u>	18
Particles >21µm		ASTM D7647	>20	12	<b>△</b> 33	6
Particles >38µm		ASTM D7647	>4	1	2	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/16/12	<u>19/18/14</u>	15/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



## **OIL ANALYSIS REPORT**







Certificate L2367

Sample No. Lab Number **Unique Number** 

: 06026453

: KCPA011493 : 10776244

Received Diagnosed

: 07 Dec 2023 Diagnostician : Doug Bogart

Test Package : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

3348 INDUSTRIAL DR WICHITA FALLS, TX

US 76306

Contact: Service Manager

T: F: