


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

KAESER BSD50T 6046077 (S/N 1380)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul2018 Aug	2019 Jun2020 May2021	Nov2021 Jun2022 Nov2022 Apr202	23 Nov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA007967	KCP53262	KCP47572D
Sample Date		Client Info		16 Nov 2023	03 Apr 2023	14 Nov 2022
Machine Age	hrs	Client Info		28144	24009	21879
Oil Age	hrs	Client Info		0	429	1998
Oil Changed		Client Info		N/A	Not Changd	Changed
Sample Status				NORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	2
Aluminum	ppm	ASTM D5185m		0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m		11	<1	<1
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	1	54	32
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	100	37	92	86
Calcium	ppm	ASTM D5185m	0	0	2	3
Phosphorus	ppm	ASTM D5185m	0	2	3	4
Zinc	ppm	ASTM D5185m	0	0	4	4
Sulfur	ppm	ASTM D5185m	23500	18896	24715	25874
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	1
Sodium	ppm	ASTM D5185m		9	13	20
Potassium	ppm	ASTM D5185m	>20	2	4	7
Water	%	ASTM D6304	>0.05	0.017	0.034	0.019
ppm Water	ppm	ASTM D6304	>500	173	343.6	196.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2755	33366	3458
Particles >6µm		ASTM D7647	>1300	558	△ 9457	704
Particles >14μm		ASTM D7647	>80	35	▲ 438	53
Particles >21μm		ASTM D7647	>20	9	▲ 57	10
Particles >38μm		ASTM D7647	>4	0	1	1
Particles >71μm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/16/12	<u>22/20/16</u>	19/17/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.41


0.38

0.36



OIL ANALYSIS REPORT





Certificate L2367

Unique Number

: 10776253

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : IND 2 (Additional Tests: KF, PrtCount)

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician : Doug Bogart

US 76051

T: F:

Contact: Service Manager