


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

KAESER ASD 25 2522317 (S/N 1038)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Apr201	9 Aug2021	Oct2022 No	ov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA011491	KCP46821	KCP42829
Sample Date		Client Info		27 Nov 2023	04 Oct 2022	16 Aug 2021
Machine Age	hrs	Client Info		108550	100932	74624
Oil Age	hrs	Client Info		0	5694	7032
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	8	2	9
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	90	38	43	16
Calcium	ppm	ASTM D5185m	2	1	0	0
Phosphorus	ppm	ASTM D5185m		<1	11	3
Zinc	ppm	ASTM D5185m		18	13	26
Sulfur	ppm	ASTM D5185m		17055	20422	16092
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		20	20	5
Potassium	ppm	ASTM D5185m	>20	3	0	2
Water	%	ASTM D6304	>0.05	0.007	0.017	0.016
ppm Water	ppm	ASTM D6304	>500	77	170.6	160.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1451	1449	2562
Particles >6µm		ASTM D7647	>1300	324	351	1054
Particles >14µm		ASTM D7647	>80	21	31	65
Particles >21µm		ASTM D7647	>20	6	6	11
Particles >38µm		ASTM D7647	>4	1	1	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/12	18/16/12	17/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

Contact/Location: Service Manager - QUEALL


0.31

Report Id: QUEALL [WUSCAR] 06026464 (Generated: 12/07/2023 10:21:37) Rev: 1

0.299



OIL ANALYSIS REPORT



Unique Number

: 10776255

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : IND 2 (Additional Tests: KF, PrtCount)

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician : Doug Bogart

US 75002

T: F:

Contact: Service Manager