


# **OIL ANALYSIS REPORT**

## Sample Rating Trend



**NORMAL** 



# B3 SARAN LINE SOUTH (S/N U152000156)

Component

Pump Fluid

**USPI VAC 100 (--- GAL)** 

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Muzdoz 1 May202 1 Sap202 1 Nov202 1 Fab202 - Ju202 2 Nov202 Fab202 Sap202 3 Dac202 3						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM31999	USPM29576	USPM26543
Sample Date		Client Info		05 Dec 2023	11 Sep 2023	27 Feb 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	18	16	9
Chromium	ppm	ASTM D5185m	>5	0	0	0
Nickel	ppm	ASTM D5185m	>5	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>7	<1	0	<1
Lead	ppm	ASTM D5185m	>12	0	0	0
Copper	ppm	ASTM D5185m	>30	<1	0	0
Tin	ppm	ASTM D5185m	>9	6	6	5
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	3
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	1
Magnesium	ppm	ASTM D5185m	0	0	0	0
Calcium	ppm	ASTM D5185m	0	2	<1	1
Phosphorus	ppm	ASTM D5185m	1800	1356	1546	1519
Zinc	ppm	ASTM D5185m	0	0	0	2
Sulfur	ppm	ASTM D5185m	0	0	8	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	<1	<1	1
Sodium	ppm	ASTM D5185m		7	4	1
Potassium	ppm	ASTM D5185m	>20	3	2	2
Water	%	ASTM D6304	>.1	0.041	0.069	0.049
ppm Water	ppm	ASTM D6304	>1000	411	698.1	498.4
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	133	147	387
Particles >6µm		ASTM D7647	>2500	49	63	108
Particles >14μm		ASTM D7647	>640	11	10	13
Particles >21µm		ASTM D7647	>160	2	2	5
Particles >38μm		ASTM D7647	>40	0	0	0
Particles >71μm		ASTM D7647	>10	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/16	14/13/11	14/13/10	16/14/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	0.92	0.83	0.59



## **OIL ANALYSIS REPORT**





Sample No. Lab Number **Unique Number** 

: 06026482 : 10776273

Received Diagnosed

: 07 Dec 2023 Diagnostician : Doug Bogart COLUMBIA, MO US 65202

Contact: Service Manager

Test Package : IND 2 Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: