


# **PROBLEM SUMMARY**

# B3 SARAN LINE SPARE (S/N U152000160)

Pump Fluid USPI VAC 100 (--- GAL)

# COMPONENT CONDITION SUMMARY



### RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status				ATTENTION	ATTENTION	NORMAL	
Visc @ 40°C	cSt	ASTM D445	91	<b>A</b> 79.3	▲ 80.11	85.2	


Customer Id: KRACOLUSP Sample No.: USPM31997 Lab Number: 06026484 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

# 11 Sep 2023 Diag: Doug Bogart



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. A decrease in the viscosity is noted. Confirmed. The AN level is acceptable for this fluid.

#### 27 Feb 2023 Diag: Doug Bogart

09 Nov 2022 Diag: Doug Bogart



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. A decrease in the viscosity is noted. Confirmed. The AN level is acceptable for this fluid.



view report



#### NORMAL



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

# B3 SARAN LINE SPARE (S/N U152000160)

Pump Fluid

USPI VAC 100 (--- GAL)

# DIAGNOSIS

## Recommendation

Resample at the next service interval to monitor.

#### Wear


All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

## Fluid Condition


A decrease in the viscosity is noted. Confirmed. The AN level is acceptable for this fluid.





SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM31997	USPM29577	USPM26544
Sample Date		Client Info		05 Dec 2023	11 Sep 2023	27 Feb 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	7	8	6
Chromium	ppm	ASTM D5185m	>5	0	0	0
Nickel	ppm	ASTM D5185m	>5	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m		0	0	<1
Lead	ppm	ASTM D5185m	>12	0	0	0
Copper	ppm	ASTM D5185m		1	0	0
Tin	ppm	ASTM D5185m	>9	<1	<1	<1
Vanadium	ppm	ASTM D5185m	20	0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	3
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	1
Magnesium	ppm	ASTM D5185m	0	<1	0	0
Calcium	ppm	ASTM D5185m	0	<1	0	<1
Phosphorus	ppm	ASTM D5185m	1800	775	810	778
Zinc	ppm	ASTM D5185m	0	0	0	3
Sulfur	ppm	ASTM D5185m	0	109	149	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	5	5	5
Sodium	ppm	ASTM D5185m		4	3	1
Potassium	ppm	ASTM D5185m	>20	2	2	1
Water	%	ASTM D6304		0.025	0.046	0.029
ppm Water	ppm	ASTM D6304	>1000	255	466.7	293.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	9737	3275	765
Particles >6µm		ASTM D7647	>2500	2077	614	217
Particles >14µm		ASTM D7647	>640	100	10	18
Particles >21µm		ASTM D7647	>160	20	3	5
Particles >38µm		ASTM D7647	>40	1	0	1
Particles >71µm		ASTM D7647	>10	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/16	20/18/14	19/16/10	17/15/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	0.22	0.56	0.17



# **OIL ANALYSIS REPORT**








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	91	<b>A</b> 79.3	▲ 80.11	85.2
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color						

Bottom



Contact/Location: Service Manager - KRACOLUSP