

PROBLEM SUMMARY

PHS AND PLS SYSTEM Machine Id RECYCLED NH3 SYSTEM 2

Component

Refrigeration Compressor


USPI ALT-68 SC (--- GAL)

m/0221 Jun/0223 Fes/0223 Mes/0223 Mes/0223 Jun/0223 Jun/0223 Ses/0223 Ses/0223 New/0223

Sample Rating Trend



COMPONENT CONDITION SUMMARY



RECOMMENDATION

This is a baseline read-out on the submitted sample.

PROBLEMATIC TEST RESULTS										
Sample Status				ABNORMAL	ABNORMAL	NORMAL				
Iron	ppm	ASTM D5185m	>8	△ 53	<u>452</u>	6				

Customer Id: SMITAR Sample No.: USP0003954 Lab Number: 06026497 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

16 Nov 2023 Diag: Doug Bogart

WEAR



This is a baseline read-out on the submitted sample. The iron level is abnormal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid.



30 Oct 2023 Diag: Doug Bogart

NORMAL



This is a baseline read-out on the submitted sample. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



02 Oct 2023 Diag: Doug Bogart

NORMAL



This is a baseline read-out on the submitted sample. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






OIL ANALYSIS REPORT

PHS AND PLS SYSTEM **RECYCLED NH3 SYSTEM 2**

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)





DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

Wear

The iron level is abnormal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		in2021 Jan20	23 Feb 2023 Mar 2023 M	ay2023 Jun2023 Aug2023 Sep203	3 Nov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0003954	USP0003641	USP0002950
Sample Date		Client Info		04 Dec 2023	16 Nov 2023	30 Oct 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	53	<u>▲</u> 452	6
Chromium	ppm	ASTM D5185m	>2	0	<1	<1
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>3	0	<1	0
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	0	0	<1
Tin	ppm	ASTM D5185m	>4	0	0	<1
Vanadium	ppm	ASTM D5185m		<1	<1	<1
Cadmium	ppm	ASTM D5185m		0	<1	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	1	<1
Magnesium	ppm	ASTM D5185m		0	2	0
Calcium	ppm	ASTM D5185m		0	2	0
Phosphorus	ppm	ASTM D5185m		0	1	0
Zinc	ppm	ASTM D5185m		0	11	0
Sulfur	ppm	ASTM D5185m	50	0	6	3
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	3	3
Sodium	ppm	ASTM D5185m		<1	2	1
Potassium	ppm	ASTM D5185m	>20	0	2	<1
Water	%	ASTM D6304	>0.01	0.004	0.009	0.003
ppm Water	ppm	ASTM D6304	>100	42	97.0	25.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>10000	1196	<u>\$\text{294784}\$</u>	390
Particles >6µm		ASTM D7647	>2500	119	<u></u> 198310	94
Particles >14µm		ASTM D7647	>320	9	<u>^</u> 2278	10
Particles >21µm		ASTM D7647	>80	2	<u>^</u> 90	5
Particles >38µm		ASTM D7647	>20	0	3	1
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	17/14/10	<u>\$\text{\Delta}\$ 25/25/18</u>	16/14/10
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.014	0.074	0.012



OIL ANALYSIS REPORT



Certificate L2367

Unique Number

Test Package

: 10776288

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

: IND 2

Diagnostician

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

: Doug Bogart

US 28392

T: F:

Contact: SERVICE MANAGER