


### **PROBLEM SUMMARY**

### Sample Rating Trend



WATER




## RECYCLED NH3

Component

Refrigeration Compressor

USPI 1009-68 SC (130 GAL)

### COMPONENT CONDITION SUMMARY



### RECOMMENDATION

This is a baseline read-out on the submitted sample.

PROBLEMATIC TEST RESULTS							
Sample Status				SEVERE	NORMAL	NORMAL	
Water	%	ASTM D6304	>0.01	<b>1.15</b>	0.004	0.005	
ppm Water	ppm	ASTM D6304	>100	<b>11500</b>	49.3	59.5	
Silt	scalar	*Visual	NONE	MODER	NONE	NONE	
Appearance	scalar	*Visual	NORML	MILKY	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.01	<b>0.2%</b>	NEG	NEG	
Free Water	scalar	*Visual		<b>1.0</b>	NEG	NEG	

Customer Id: TYSEMPPRO Sample No.: USP0003925 Lab Number: 06026514 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

### 08 Dec 2022 Diag: Doug Bogart

NORMAL



This is a baseline read-out on the submitted sample. 1ST SAMPLE AFTER There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 09 Nov 2022 Diag: Doug Bogart

NORMAL



This is a baseline read-out on the submitted sample. 238844 SAMPLE3 AFTER There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 02 Oct 2022 Diag: Doug Bogart

ISO



This is a baseline read-out on the submitted sample. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





### **OIL ANALYSIS REPORT**

### Sample Rating Trend





# RECYCLED NH3

**Refrigeration Compressor** 

USPI 1009-68 SC (130 GAL)

### DIAGNOSIS

### Recommendation

This is a baseline read-out on the submitted sample.

#### Contamination

Appearance is milky. There is a high concentration of water present in the oil. There is a moderate amount of visible silt present in the sample. Free water present.

#### **Fluid Condition**

The AN level is acceptable for this fluid.

		y2018 Jul20	19 Jan2020 Jan2020	Dec2020 Dec2020 May2021 \$	ep2022	
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0003925	USP238848	USP238852
Sample Date		Client Info		05 Dec 2023	08 Dec 2022	09 Nov 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	0
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	0
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	0	<1	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	<1	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	<1	0
Zinc	ppm	ASTM D5185m		0	<1	0
Sulfur	ppm	ASTM D5185m	50	0	13	17
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	2	1
Sodium	ppm	ASTM D5185m		<1	<1	0
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304	>0.01	<b>1.15</b>	0.004	0.005
ppm Water	ppm	ASTM D6304	>100	<b>11500</b>	49.3	59.5
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			367	2048
Particles >6µm		ASTM D7647	>2500		119	338
Particles >14µm		ASTM D7647	>320		10	19
Particles >21µm		ASTM D7647	>80		3	7
Particles >38µm		ASTM D7647	>20		0	0
Particles >71µm		ASTM D7647	>4		0	0
Oil Cleanliness		ISO 4406 (c)	>/18/15		16/14/10	18/16/11
FLUID DEGRADA	TION _	method	limit/base	current	history1	history2

mg KOH/g ASTM D974 0.005

Acid Number (AN)


0.015

0.03


0.015



### **OIL ANALYSIS REPORT**



,	Acid N	lumbe	er						
0.16 T	100000	11111		51333	1011111				
_ 0.14-									
중 0.12-	-								
g 0.10				4					
0.08									
50.06									
Acid Number (mg KOH/g) 90.0 0	1		Λ	444	A	للتثث	Α.		
0.02+	N		∕∖	اللالقا	∕∖∟	تنتينا	∠∖∖		1
0.00	Bäse V	1							
0.5	0 /0	9/19	6/20	0/20	9/20	9/20	2/21	4/22	
0.7	VIdy	Jul29/	Jan 16/	Jan 20	Jec16/	Dec16/	May12	Sep14/	
			-	-	_	_			



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ MILKY	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.01	<b>0.2%</b>	NEG	NEG
Free Water	scalar	*Visual		<b>1.0</b>	NEG	NEG


FLUID FROFER	IIES	memou	IIIIII/Dase	Current	HISTOLAL	HISTOLYZ
Visc @ 40°C	cSt	ASTM D445	67	64.1	66.2	62.9


SAMPLE	IMAGES


Color


**Bottom** 

### **GRAPHS**













Certificate L2367

Laboratory Sample No. Lab Number Test Package : IND 2

Unique Number : 10776305

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : USP0003925 : 06026514

Received : 06 Dec 2023 : 07 Dec 2023 Diagnosed Diagnostician : Doug Bogart TYSON FOODS - EMPORIA PROCESSING

2101 WEST SIXTH EMPORIA, KS US 66801

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: