


# PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id  
**C-1163**  
Component  
**Refrigeration Compressor**  
Fluid  
**TULCO LUBSOIL SYN RL WI 100 (--- GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time.  
Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ATTENTION	ABNORMAL	---
Particles >4µm	ASTM D7647	>10000	▲ 19448	▲ 66492	---
Particles >6µm	ASTM D7647	>2500	▲ 4828	▲ 15638	---
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 21/19/15	▲ 23/21/16	---

Customer Id: ETKEN  
Sample No.: TO90002476  
Lab Number: 06026524  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

**20 Jun 2022 Diag: Don Baldrige**

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report





Machine Id  
**C-1163**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**TULCO LUBSOIL SYN RL WI 100 (--- GAL)**



**DIAGNOSIS**

**Recommendation**  
 No corrective action is recommended at this time. Resample at the next service interval to monitor.

**Wear**  
 All component wear rates are normal.

**Contamination**  
 There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

**Fluid Condition**  
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

**SAMPLE INFORMATION**

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>TO90002476</b>	TO90001778	---
Sample Date	Client Info	<b>05 Dec 2023</b>	20 Jun 2022	---
Machine Age	hrs	Client Info	<b>0</b>	0
Oil Age	hrs	Client Info	<b>0</b>	0
Oil Changed	Client Info	<b>N/A</b>	N/A	---
Sample Status		<b>ATTENTION</b>	ABNORMAL	---

**WEAR METALS**

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >8	<b>5</b>	3
Chromium	ppm	ASTM D5185m >2	<b>0</b>	0
Nickel	ppm	ASTM D5185m	<b>&lt;1</b>	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	<1
Aluminum	ppm	ASTM D5185m >3	<b>&lt;1</b>	<1
Lead	ppm	ASTM D5185m >2	<b>0</b>	0
Copper	ppm	ASTM D5185m >8	<b>0</b>	<1
Tin	ppm	ASTM D5185m >4	<b>1</b>	1
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0

**ADDITIVES**

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	3
Barium	ppm	ASTM D5185m	<b>0</b>	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0
Magnesium	ppm	ASTM D5185m	<b>0</b>	0
Calcium	ppm	ASTM D5185m	<b>2</b>	0
Phosphorus	ppm	ASTM D5185m 1500	<b>462</b>	677
Zinc	ppm	ASTM D5185m	<b>57</b>	22
Sulfur	ppm	ASTM D5185m	<b>0</b>	0

**CONTAMINANTS**

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>&lt;1</b>	2
Sodium	ppm	ASTM D5185m	<b>3</b>	3
Potassium	ppm	ASTM D5185m >20	<b>1</b>	0
Water	%	ASTM D6304 >2.26	<b>0.118</b>	0.165
ppm Water	ppm	ASTM D6304 >22600	<b>1183</b>	1655.2






**FLUID CLEANLINESS**

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	<b>▲ 19448</b>	▲ 66492	---
Particles >6µm	ASTM D7647 >2500	<b>▲ 4828</b>	▲ 15638	---
Particles >14µm	ASTM D7647 >320	<b>243</b>	▲ 631	---
Particles >21µm	ASTM D7647 >80	<b>46</b>	76	---
Particles >38µm	ASTM D7647 >20	<b>1</b>	2	---
Particles >71µm	ASTM D7647 >4	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c) >20/18/15	<b>▲ 21/19/15</b>	▲ 23/21/16	---

**FLUID DEGRADATION**

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974 0.04	<b>0.066</b>	0.057


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	LIGHT	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>2.26	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	97	103	---
Visc @ 100°C	cSt	ASTM D445	17.5	19.2	---
Viscosity Index (VI)	Scale	ASTM D2270	198	209	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO90002476 **Received** : 06 Dec 2023  
**Lab Number** : 06026524 **Diagnosed** : 07 Dec 2023  
**Unique Number** : 10776315 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KV100, PrtCount, VI )

**ETC - KENEDY**

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

US  
 Contact: STEVEN GWOSDZ  
 steven.gwosdz@energytransfer.com  
 T:  
 F: