


# PROBLEM SUMMARY

Area  
**Jackson County 3 Plant/Cryogenic/Compressor**  
 Machine Id  
**C-3163 (S/N 10241B31315891)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**SUMMIT PGS-100 (250 GAL)**

Sample Rating Trend




**WATER**




## COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Water (KF)



## RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	SEVERE	ABNORMAL
Water	%	ASTM D6304	>0.01	▲ 0.078	● 2.411	▲ 0.618
ppm Water	ppm	ASTM D6304	>100	▲ 790	● 24114.1	▲ 6180
Particles >4µm		ASTM D7647	>2500	▲ 10078	▲ 12165	▲ 13439
Particles >6µm		ASTM D7647	>320	▲ 2762	▲ 850	▲ 1423
Particles >14µm		ASTM D7647	>80	▲ 270	15	31
Particles >21µm		ASTM D7647	>20	▲ 88	4	4
Particles >38µm		ASTM D7647	>4	▲ 7	1	0
Oil Cleanliness		ISO 4406 (c)	>18/15/13	▲ 21/19/15	▲ 21/17/11	▲ 21/18/12

Customer Id: ETCJCTY  
 Sample No.: TO50001822  
 Lab Number: 06026535  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.

## HISTORICAL DIAGNOSIS

**04 Jun 2023 Diag: Jonathan Hester**

WATER



We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a high concentration of water present in the oil. The AN level is acceptable for this fluid.

view report



**27 Oct 2022 Diag: Don Baldrige**

WATER



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



**20 Jun 2022 Diag: Don Baldrige**

WATER




We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Area  
**Jackson County 3 Plant/Cryogenic/Compressor**  
 Machine Id  
**C-3163 (S/N 10241B31315891)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**SUMMIT PGS-100 (250 GAL)**

**DIAGNOSIS**

**Recommendation**  
 We recommend you service the filters on this component. Resample at the next service interval to monitor.

**Wear**  
 All component wear rates are normal.

**Contamination**  
 There is a high amount of particulates present in the oil. There is a trace of moisture present in the oil.

**Fluid Condition**  
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>TO50001822</b>	TO90002073	TO90002069
Sample Date	Client Info		<b>05 Dec 2023</b>	04 Jun 2023	27 Oct 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	SEVERE	ABNORMAL

WEAR METALS	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >8	<b>5</b>	4	4
Chromium	ppm	ASTM D5185m >2	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	<b>&lt;1</b>	0	3
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >3	<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D5185m >2	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >8	<b>0</b>	<1	<1
Tin	ppm	ASTM D5185m >4	<b>1</b>	<1	<1
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

ADDITIVES	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 2	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m 0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m 0	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m 0	<b>0</b>	<1	<1
Calcium	ppm	ASTM D5185m 0	<b>0</b>	0	3
Phosphorus	ppm	ASTM D5185m 0	<b>1258</b>	451	347
Zinc	ppm	ASTM D5185m 0	<b>37</b>	29	43
Sulfur	ppm	ASTM D5185m 5	<b>0</b>	0	30


CONTAMINANTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>&lt;1</b>	3	5
Sodium	ppm	ASTM D5185m	<b>16</b>	6	5
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	3	<1
Water	%	ASTM D6304 >0.01	<b>▲ 0.078</b>	2.411	▲ 0.618
ppm Water	ppm	ASTM D6304 >100	<b>▲ 790</b>	24114.1	▲ 6180

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	<b>▲ 10078</b>	▲ 12165	▲ 13439
Particles >6µm	ASTM D7647	>320	<b>▲ 2762</b>	▲ 850	▲ 1423
Particles >14µm	ASTM D7647	>80	<b>▲ 270</b>	15	31
Particles >21µm	ASTM D7647	>20	<b>▲ 88</b>	4	4
Particles >38µm	ASTM D7647	>4	<b>▲ 7</b>	1	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>18/15/13	<b>▲ 21/19/15</b>	▲ 21/17/11	▲ 21/18/12


FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974 0.1	<b>0.038</b>	0.12	0.09

# OIL ANALYSIS REPORT


### ▲ Particle Trend




### ▲ Water (KF)




### ▲ Viscosity @ 100°C



### ▲ Acid Number



### ▲ Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	100	99.7	98.71
Visc @ 100°C	cSt	ASTM D445	19.4	18.6	17.8
Viscosity Index (VI)	Scale	ASTM D2270	218	207	199

### SAMPLE IMAGES

Color




Bottom




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### ▲ Particle Count



#### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO50001822 **Received** : 06 Dec 2023  
**Lab Number** : 06026535 **Diagnosed** : 07 Dec 2023  
**Unique Number** : 10776326 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KV100, PrtCount, VI )

**ETC - JACKSON COUNTY**

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

US  
Contact: Service Manager

T:  
F: