


# PROBLEM SUMMARY

Sample Rating Trend




**WATER**




Area  
**Jackson County 2 Plant/Cryogenic/Compressor**  
Machine Id  
**C-2161 (S/N 10241D20819396)**  
Component  
**Refrigeration Compressor**  
Fluid  
**SUMMIT PGS-100 (250 GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Water (KF)



## RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status	%	ASTM D6304	>	ABNORMAL	ABNORMAL	ABNORMAL
Water	%	ASTM D6304	>0.01	▲ 0.093	▲ 0.097	▲ 0.432
ppm Water	ppm	ASTM D6304	>100	▲ 932	▲ 973.6	▲ 4320
Particles >4µm		ASTM D7647	>2500	▲ 95594	▲ 68095	▲ 68155
Particles >6µm		ASTM D7647	>320	▲ 26742	▲ 8341	▲ 6769
Particles >14µm		ASTM D7647	>80	▲ 1484	▲ 143	▲ 122
Particles >21µm		ASTM D7647	>20	▲ 366	15	17
Particles >38µm		ASTM D7647	>4	▲ 16	1	1
Oil Cleanliness		ISO 4406 (c)	>18/15/13	▲ 24/22/18	▲ 23/20/14	▲ 23/20/14

Customer Id: ETCJCTY  
Sample No.: TO90002480  
Lab Number: 06026537  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.

## HISTORICAL DIAGNOSIS

### 04 Jun 2023 Diag: Jonathan Hester

#### WATER



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 27 Oct 2022 Diag: Don Baldrige

#### WATER



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 20 Jun 2022 Diag: Don Baldrige

#### WATER



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)




# OIL ANALYSIS REPORT

Sample Rating Trend

**WATER**

Area  
**Jackson County 2 Plant/Cryogenic/Compressor**  
 Machine Id  
**C-2161 (S/N 10241D20819396)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**SUMMIT PGS-100 (250 GAL)**



## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>TO90002480</b>	TO90002483	TO90002066
Sample Date	Client Info	<b>05 Dec 2023</b>	04 Jun 2023	27 Oct 2022
Machine Age	hrs	<b>0</b>	0	0
Oil Age	hrs	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >8	<b>3</b>	4	5
Chromium	ppm	ASTM D5185m >2	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	<b>&lt;1</b>	0	2
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185m >3	<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D5185m >2	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >8	<b>&lt;1</b>	<1	2
Tin	ppm	ASTM D5185m >4	<b>1</b>	1	2
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 2	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m 0	<b>0</b>	0	<1
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m 0	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m 0	<b>0</b>	<1	<1
Calcium	ppm	ASTM D5185m 0	<b>0</b>	11	11
Phosphorus	ppm	ASTM D5185m 0	<b>38</b>	18	19
Zinc	ppm	ASTM D5185m 0	<b>75</b>	63	58
Sulfur	ppm	ASTM D5185m 5	<b>0</b>	0	17

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	<b>7</b>	3	4
Sodium	ppm	ASTM D5185m	<b>10</b>	4	6
Potassium	ppm	ASTM D5185m >20	<b>0</b>	3	1
Water	%	ASTM D6304 >0.01	<b>▲ 0.093</b>	▲ 0.097	▲ 0.432
ppm Water	ppm	ASTM D6304 >100	<b>▲ 932</b>	▲ 973.6	▲ 4320

## FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >2500	<b>▲ 95594</b>	▲ 68095	▲ 68155
Particles >6µm	ASTM D7647 >320	<b>▲ 26742</b>	▲ 8341	▲ 6769
Particles >14µm	ASTM D7647 >80	<b>▲ 1484</b>	▲ 143	▲ 122
Particles >21µm	ASTM D7647 >20	<b>▲ 366</b>	15	17
Particles >38µm	ASTM D7647 >4	<b>▲ 16</b>	1	1
Particles >71µm	ASTM D7647 >3	<b>1</b>	0	0
Oil Cleanliness	ISO 4406 (c) >18/15/13	<b>▲ 24/22/18</b>	▲ 23/20/14	▲ 23/20/14

## FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974 0.1	<b>0.034</b>	0.125	0.046

# OIL ANALYSIS REPORT


### ▲ Particle Trend




### ▲ Water (KF)




### ▲ Viscosity @ 100°C



### ▲ Acid Number




### ▲ Viscosity @ 100°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	100	90.8	93.13
Visc @ 100°C	cSt	ASTM D445	19.4	15.7	16.3
Viscosity Index (VI)	Scale	ASTM D2270	218	184	189

### SAMPLE IMAGES




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### ▲ Particle Count



#### ▲ Acid Number



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO90002480 **Received** : 06 Dec 2023  
**Lab Number** : 06026537 **Diagnosed** : 07 Dec 2023  
**Unique Number** : 10776328 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KV100, PrtCount, VI )

**ETC - JACKSON COUNTY**  
 US  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)