




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**CATERPILLAR GM02**  
 Component  
**Biogas Engine**  
 Fluid  
**MAHLER Q8 Mahler G8 SAE 40 (--- GAL)**

## DIAGNOSIS

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0870530</b>	WC0870533	WC0870535
Sample Date	Client Info			<b>05 Dec 2023</b>	01 Dec 2023	29 Nov 2023
Machine Age	hrs	Client Info		<b>66613</b>	66523	66475
Oil Age	hrs	Client Info		<b>90</b>	0	461
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	ABNORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>4.0		<b>&lt;1.0</b>	<1.0	<1.0
Water	WC Method	>0.1		<b>NEG</b>	NEG	NEG
Glycol	WC Method			<b>NEG</b>	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>45	<b>6</b>	3	14
Chromium	ppm	ASTM D5185m	>2	<b>&lt;1</b>	0	<1
Nickel	ppm	ASTM D5185m	>2	<b>&lt;1</b>	0	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	<1	0
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>10	<b>2</b>	1	4
Lead	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>14	<b>&lt;1</b>	<1	1
Tin	ppm	ASTM D5185m	>13	<b>&lt;1</b>	0	3
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>0</b>	0	0
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Manganese	ppm	ASTM D5185m		<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m		<b>4</b>	4	7
Calcium	ppm	ASTM D5185m		<b>1334</b>	1346	1378
Phosphorus	ppm	ASTM D5185m		<b>362</b>	405	381
Zinc	ppm	ASTM D5185m		<b>428</b>	428	459
Sulfur	ppm	ASTM D5185m		<b>1870</b>	2013	1995




CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>200	<b>75</b>	18	▲ 239
Sodium	ppm	ASTM D5185m		<b>0</b>	0	1
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	2	0

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		<b>0</b>	0	0
Nitration	Abs/cm	*ASTM D7624	>20	<b>4.8</b>	4.2	5.7
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>15.0</b>	14.5	16.8

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>9.3</b>	8.6	11.1
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.28</b>	0.47	1.35
Base Number (BN)	mg KOH/g	ASTM D2896	8.0	<b>5.79</b>	6.41	5.00











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	13.2	<b>13.3</b>	13.2	13.7

### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0870530 **Received** : 06 Dec 2023  
**Lab Number** : **06027202** **Diagnosed** : 08 Dec 2023  
**Unique Number** : 10776993 **Diagnostician** : Angela Borella  
**Test Package** : MOB 2

**OAK GROVE KS**  
 1150 E 700TH AVE  
 ARCADIA, KS  
 US 66711  
 Contact: KALEB WEAVER  
 kaleb.weaver@cubedistrictenergy.com  
 T:  
 F:

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)