




# PROBLEM SUMMARY

Sample Rating Trend


ISO

Area  
**Powerblock**  
 Machine Id  
**KAMENGO KAMENGO HPU (S/N PHS01233RER)**  
 Component  
**Bulk Fluid Tank**  
 Fluid  
**Royal Purple biomass EAL hydraulic oil 46 (--- GAL)**



## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. ( Customer Sample Comment: Both pumps failed and were replaced. )

## PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	NORMAL
Particles >4µm	ASTM D7647	>5000	▲ <b>64276</b>	▲ 28098	4540
Particles >6µm	ASTM D7647	>1300	▲ <b>13730</b>	▲ 11249	972
Particles >14µm	ASTM D7647	>160	▲ <b>573</b>	▲ 1210	90
Particles >21µm	ASTM D7647	>40	▲ <b>131</b>	▲ 346	38
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ <b>23/21/16</b>	▲ 22/21/17	19/17/14

Customer Id: VEOCAR  
 Sample No.: WC0839392  
 Lab Number: 06027268  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 01 Nov 2023 Diag: Angela Borella

ISO



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 16 Jun 2023 Diag: Jonathan Hester

NORMAL



This is a baseline read-out on the submitted sample.

view report



### 21 Mar 2023 Diag: Jonathan Hester

VIS DEBRIS



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**Powerblock**  
 Machine Id  
**KAMENGO KAMENGO HPU (S/N PHS01233RER)**  
 Component  
**Bulk Fluid Tank**  
 Fluid  
**Royal Purple biomass EAL hydraulic oil 46 (--- GAL)**

## DIAGNOSIS

### Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. ( Customer Sample Comment: Both pumps failed and were replaced. )

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0839392</b>	WC0814538	WC0814553
Sample Date	Client Info		<b>04 Dec 2023</b>	01 Nov 2023	16 Jun 2023
Machine Age	hrs	Client Info	<b>26281</b>	60	26280
Oil Age	hrs	Client Info	<b>6</b>	3	26280
Oil Changed	Client Info		<b>N/A</b>	Filtered	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	<b>29</b>	38	1
Chromium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>1</b>	1	2
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	<b>2</b>	0	1
Lead	ppm	ASTM D5185m	<b>3</b>	2	2
Copper	ppm	ASTM D5185m	<b>24</b>	6	19
Tin	ppm	ASTM D5185m	<b>&lt;1</b>	<1	2
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	0	2
Calcium	ppm	ASTM D5185m	<b>98</b>	86	105
Phosphorus	ppm	ASTM D5185m	<b>566</b>	515	653
Zinc	ppm	ASTM D5185m	<b>12</b>	23	18
Sulfur	ppm	ASTM D5185m	<b>6335</b>	6319	8569

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Sodium	ppm	ASTM D5185m	<b>4</b>	5	<1
Potassium	ppm	ASTM D5185m >20	<b>1</b>	2	1


## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>▲ 64276</b>	▲ 28098	4540
Particles >6µm	ASTM D7647	>1300	<b>▲ 13730</b>	▲ 11249	972
Particles >14µm	ASTM D7647	>160	<b>▲ 573</b>	▲ 1210	90
Particles >21µm	ASTM D7647	>40	<b>▲ 131</b>	▲ 346	38
Particles >38µm	ASTM D7647	>10	<b>7</b>	▲ 22	6
Particles >71µm	ASTM D7647	>3	<b>0</b>	2	1
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>▲ 23/21/16</b>	▲ 22/21/17	19/17/14


## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>1.83</b>	1.29	1.82


### ▲ Particle Trend




### ● Viscosity @ 100°C




### Acid Number



### ● Viscosity @ 40°C



### ● Viscosity @ 100°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	43.89	43.31	43.61
Visc @ 100°C	cSt	ASTM D445	8.04	8.04	8.22
Viscosity Index (VI)	Scale	ASTM D2270	157	160	166

### SAMPLE IMAGES


Color




Bottom

### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### ▲ Particle Count



#### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0839392 **Received** : 06 Dec 2023  
**Lab Number** : 06027268 **Diagnosed** : 11 Dec 2023  
**Unique Number** : 10777059 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KV100, PrtCount, VI )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**VEOLIA ENERGY - FRANKLIN**  
 3465 HWY 198  
 CARNESVILLE, GA  
 US 30521  
 Contact: DERRICK HARVEY  
 derrick.harvey@veolia.com

T:  
F: