



# OIL ANALYSIS REPORT

Sample Rating Trend

WATER



Area  
**RIG 274**  
 Machine Id  
**R274-MP-03**  
 Component  
**Gearbox**  
 Fluid  
**NOT GIVEN (--- GAL)**



## DIAGNOSIS

### Recommendation

We advise that you check for the source of water entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Else, we recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

### Wear

Gear wear is indicated.

### Contamination

Appearance is milky. There is a high concentration of water present in the oil. The high sodium (Na) level indicates the possible presence of salt water. Elemental levels of silicon (Si) and aluminum (Al) indicate alumina-silicate (coarse dirt) ingress.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KL0013160</b>	---	---
Sample Date	Client Info		<b>01 Dec 2023</b>	---	---
Machine Age	hrs	Client Info	<b>0</b>	---	---
Oil Age	hrs	Client Info	<b>0</b>	---	---
Oil Changed	Client Info		<b>N/A</b>	---	---
Sample Status			<b>SEVERE</b>	---	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	<b>▲ 202</b>	---
Chromium	ppm	ASTM D5185m	>10	<b>1</b>	---
Nickel	ppm	ASTM D5185m	>10	<b>1</b>	---
Titanium	ppm	ASTM D5185m		<b>1</b>	---
Silver	ppm	ASTM D5185m		<b>0</b>	---
Aluminum	ppm	ASTM D5185m	>25	<b>▲ 36</b>	---
Lead	ppm	ASTM D5185m	>50	<b>0</b>	---
Copper	ppm	ASTM D5185m	>200	<b>24</b>	---
Tin	ppm	ASTM D5185m	>10	<b>&lt;1</b>	---
Vanadium	ppm	ASTM D5185m		<b>0</b>	---
Cadmium	ppm	ASTM D5185m		<b>&lt;1</b>	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>17</b>	---
Barium	ppm	ASTM D5185m		<b>12</b>	---
Molybdenum	ppm	ASTM D5185m		<b>&lt;1</b>	---
Manganese	ppm	ASTM D5185m		<b>2</b>	---
Magnesium	ppm	ASTM D5185m		<b>29</b>	---
Calcium	ppm	ASTM D5185m		<b>249</b>	---
Phosphorus	ppm	ASTM D5185m		<b>169</b>	---
Zinc	ppm	ASTM D5185m		<b>30</b>	---
Sulfur	ppm	ASTM D5185m		<b>9536</b>	---

## CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<b>▲ 120</b>	---
Sodium	ppm	ASTM D5185m		<b>▲ 1704</b>	---
Potassium	ppm	ASTM D5185m	>20	<b>18</b>	---
Water	%	ASTM D6304	>0.2	<b>● 2.54</b>	---
ppm Water	ppm	ASTM D6304	>2000	<b>● 25400</b>	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.38</b>	---



# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	▲ MILKY	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.2	▲ 0.2%	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	338	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color				no image	no image
Bottom				no image	no image

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KL0013160 **Received** : 07 Dec 2023  
**Lab Number** : 06027706 **Diagnosed** : 08 Dec 2023  
**Unique Number** : 10777497 **Diagnostician** : Doug Bogart  
**Test Package** : MOB 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**PATTERSON - UTI DRILLING**  
 9915 WEST INDUSTRIAL  
 MIDLAND, TX  
 US 79706  
 Contact: RICKY MATA  
 ricky.mata@patenergy.com  
 T: (832)219-4559  
 F: (432)561-9388