




PROBLEM SUMMARY

Area
PRE PRESS
Machine Id
0720 PR02

Component
Lower Gearbox
Fluid
KLUBER Klübersynth GH 6 ISO 320 (50 LTR)



Sample Rating Trend



WATER



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	SEVERE	ATTENTION
Water	%	ASTM D6304	>0.2	▲ 0.717	● 1.008	---
ppm Water	ppm	ASTM D6304	>2000	▲ 7178	● 10080.9	---
Particles >4µm		ASTM D7647	>20000	▲ 54416	▲ 65735	▲ 39865
Oil Cleanliness		ISO 4406 (c)	>21/19/16	▲ 23/19/15	▲ 23/20/15	▲ 22/18/13

Customer Id: FLAMONNC
Sample No.: WC0806873
Lab Number: 06027731
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

18 Jul 2023 Diag: Don Baldrige

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a high concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

[view report](#)



20 Apr 2023 Diag: Wes Davis

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



14 Apr 2021 Diag: Jonathan Hester

ISO



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
PRE PRESS
Machine Id
0720 PR02

Component
Lower Gearbox
Fluid
KLUBER Klübersynth GH 6 ISO 320 (50 LTR)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 6 microns in size) present in the oil. There is a moderate concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0806873	WC0806864	WC0730514
Sample Date	Client Info		19 Oct 2023	18 Jul 2023	20 Apr 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	Not Changd	Not Changd
Sample Status			ABNORMAL	SEVERE	ATTENTION

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		39	39	---
Iron	ppm	ASTM D5185m >200	25	7	6
Chromium	ppm	ASTM D5185m >15	<1	<1	<1
Nickel	ppm	ASTM D5185m >15	<1	0	<1
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	5	<1	0
Lead	ppm	ASTM D5185m >100	0	0	0
Copper	ppm	ASTM D5185m >200	<1	<1	0
Tin	ppm	ASTM D5185m >25	<1	0	0
Antimony	ppm	ASTM D5185m >5	---	---	---
Vanadium	ppm	ASTM D5185m	<1	<1	<1
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	10	1	0
Barium	ppm	ASTM D5185m	5	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	0	0
Magnesium	ppm	ASTM D5185m	2	<1	<1
Calcium	ppm	ASTM D5185m	9	2	1
Phosphorus	ppm	ASTM D5185m 2450	2750	1817	1855
Zinc	ppm	ASTM D5185m	124	35	33
Sulfur	ppm	ASTM D5185m	59	50	41

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	23	17	21
Sodium	ppm	ASTM D5185m	17	5	3
Potassium	ppm	ASTM D5185m >20	5	<1	<1
Water	%	ASTM D6304 >0.2	▲ 0.717	1.008	---
ppm Water	ppm	ASTM D6304 >2000	▲ 7178	10080.9	---

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 54416	▲ 65735	▲ 39865
Particles >6µm	ASTM D7647	>5000	3340	▲ 5200	2499
Particles >14µm	ASTM D7647	>640	216	180	73
Particles >21µm	ASTM D7647	>160	93	55	25
Particles >38µm	ASTM D7647	>40	6	3	1
Particles >71µm	ASTM D7647	>10	0	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 23/19/15	▲ 23/20/15	▲ 22/18/13



OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.955	3.07	3.11	1.38






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	336.9	368	345	341

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0806873
Lab Number : 06027731
Unique Number : 10777522
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)
Received : 07 Dec 2023
Diagnosed : 08 Dec 2023
Diagnostician : Doug Bogart

ARAUCO FLAKEBOARD - MDF
 985 CORINTH RD
 MONCURE, NC
 US
 Contact: CHRISTOPHER JACKSON
 christopher.jackson@arauco.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)