




PROBLEM SUMMARY

Area
REFINER
Machine Id
0225SC01

Component
Gearbox
Fluid
KLUBER Klübersynth GH 6 460 (50 GAL)

Sample Rating Trend




ISO



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time.
Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status		ATTENTION	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647 >5000	▲ 7759	▲ 11044	▲ 18620
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 20/17/14	▲ 21/17/14	▲ 21/19/14

Customer Id: FLAMONNC
Sample No.: WC0842400
Lab Number: 06027734
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

01 Aug 2023 Diag: Don Baldrige

WATER



We advise that you check for the source of water entry. We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



04 May 2023 Diag: Don Baldrige

DEGRADATION



The oil is near the end of its useful service life, recommend schedule an oil change. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is at the top-end of the recommended limit.

view report



31 Jan 2023 Diag: Don Baldrige

WATER



The oil is near the end of its useful service life, recommend schedule an oil change. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a light concentration of water present in the oil. The AN level is at the top-end of the recommended limit.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
REFINER
 Machine Id
0225SC01

Component
Gearbox
 Fluid
KLUBER Klübersynth GH 6 460 (50 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 6 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0842400	WC0806866	WC0730503
Sample Date	Client Info		30 Oct 2023	01 Aug 2023	04 May 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	Not Changd	Not Changd
Sample Status			ATTENTION	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		39	28	---
Iron	ppm	ASTM D5185m >200	<1	1	<1
Chromium	ppm	ASTM D5185m >15	<1	<1	<1
Nickel	ppm	ASTM D5185m >15	0	0	<1
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	3	<1	0
Lead	ppm	ASTM D5185m >100	0	0	0
Copper	ppm	ASTM D5185m >200	<1	<1	0
Tin	ppm	ASTM D5185m >25	0	0	0
Vanadium	ppm	ASTM D5185m	<1	<1	<1
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	<1	0
Barium	ppm	ASTM D5185m	5	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	0	0	0
Magnesium	ppm	ASTM D5185m	<1	<1	<1
Calcium	ppm	ASTM D5185m	0	1	0
Phosphorus	ppm	ASTM D5185m	2186	1976	1925
Zinc	ppm	ASTM D5185m	16	14	14
Sulfur	ppm	ASTM D5185m	0	2	129

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	23	26	25
Sodium	ppm	ASTM D5185m	7	6	2
Potassium	ppm	ASTM D5185m >20	3	<1	0
Water	%	ASTM D6304 >0.2	0.00	▲ 0.514	---
ppm Water	ppm	ASTM D6304 >2000	0	▲ 5143.6	---






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ 7759	▲ 11044	▲ 18620
Particles >6µm	ASTM D7647	>1300	669	▲ 1279	▲ 3216
Particles >14µm	ASTM D7647	>160	91	94	135
Particles >21µm	ASTM D7647	>40	29	27	34
Particles >38µm	ASTM D7647	>10	2	1	1
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 20/17/14	▲ 21/17/14	▲ 21/19/14

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	3.01	2.86	▲ 3.01

OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 460	451	454	461

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0842400 **Received** : 07 Dec 2023
Lab Number : 06027734 **Diagnosed** : 08 Dec 2023
Unique Number : 10777525 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

ARAUCO FLAKEBOARD - MDF
 985 CORINTH RD
 MONCURE, NC
 US
 Contact: JAMES WALTON
 james.walton@arauco.com
 T: (919)642-6696
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)