

### **PROBLEM SUMMARY**


Sample Rating Trend

ISO


# Machine Id KAESER AS 30 7458098 (S/N 1614)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)



### **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	NORMAL	ABNORMAL				
Particles >6µm	ASTM D7647	>1300	<b>2943</b>	133	▲ 3806				
Particles >14μm	ASTM D7647	>80	<b>208</b>	8	<b>▲</b> 85				
Particles >21µm	ASTM D7647	>20	<b>48</b>	2	14				
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>2</b> 1/19/15	16/14/10	21/19/14				

Customer Id: FIBGRA Sample No.: KCP27095 Lab Number: 06027755 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

### 15 Jun 2023 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 15 Dec 2022 Diag: Don Baldridge

ISO



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 01 Aug 2022 Diag: Doug Bogart

ISO




No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





### **OIL ANALYSIS REPORT**



## KAESER AS 30 7458098 (S/N 1614)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jun 2021	Dec2021 Aug2022	Dec2022 Jun2023	Nov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP27095	KC120624	KC106908
Sample Date		Client Info		20 Nov 2023	15 Jun 2023	15 Dec 2022
Machine Age	hrs	Client Info		12387	10293	8330
Oil Age	hrs	Client Info		2093	0	0
Oil Changed		Client Info		Not Changd	N/A	Not Changd
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	1
Aluminum	ppm	ASTM D5185m	>10	2	0	2
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	8	4	2
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	7	0	63
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	90	33	12	68
Calcium	ppm	ASTM D5185m	2	0	<1	4
Phosphorus	ppm	ASTM D5185m		31	0	6
Zinc	ppm	ASTM D5185m		3	0	5
Sulfur	ppm	ASTM D5185m		20846	19993	19447
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	<1
Sodium	ppm	ASTM D5185m		11	3	2
Potassium	ppm	ASTM D5185m	>20	3	<1	2
Water	%	ASTM D6304	>0.05	0.027	0.011	0.021
ppm Water	ppm	ASTM D6304	>500	279	115.4	218.1
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		11532	531	18682
Particles >6µm		ASTM D7647	>1300	<u>^</u> 2943	133	▲ 3806
Particles >14µm		ASTM D7647	>80	<b>208</b>	8	<b>▲</b> 85
Particles >21µm		ASTM D7647	>20	<b>48</b>	2	14
Particles >38µm		ASTM D7647	>4	2	0	1
Particles >71µm		ASTM D7647	>3	0	0	1
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>21/19/15</u>	16/14/10	<u>^</u> 21/19/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.29	0.30	0.45



### **OIL ANALYSIS REPORT**



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: