


# **OIL ANALYSIS REPORT**

## **Sample Rating Trend**





Machine Id L16
Component Pump
Fluid

**USPI VAC 100 (--- LTR)** 

#### DIAGNOSIS

## Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jan2021	Jun2021 Des2021	Jun2022 Dec2022 May2023	Nov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM31931	USPM29400	USPM28431
Sample Date		Client Info		29 Nov 2023	18 Aug 2023	22 May 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	0	<1	0
Chromium	ppm	ASTM D5185m	>5	<1	0	<1
Nickel	ppm	ASTM D5185m	>5	0	0	<1
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>7	0	0	0
Lead	ppm	ASTM D5185m	>12	0	0	<1
Copper	ppm	ASTM D5185m	>30	0	0	0
Tin	ppm	ASTM D5185m	>9	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	1	<1	2
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	0	0	<1	0
Calcium	ppm	ASTM D5185m	0	0	2	0
Phosphorus	ppm	ASTM D5185m	1800	1322	1367	1383
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	0	0	32	<1
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	29	25	23
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	1	0	2
Water	%	ASTM D6304		0.037	0.049	0.037
ppm Water	ppm	ASTM D6304	>1000	377	498.2	370.1
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	85	213	122
Particles >6µm		ASTM D7647	>2500	28	62	60
Particles >14μm		ASTM D7647	>640	6	18	18
Particles >21µm		ASTM D7647	>160	2	5	7
Particles >38µm		ASTM D7647	>40	0	1	1
Particles >71μm		ASTM D7647	>10	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/16	14/12/10	15/13/11	14/13/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A -! -! NI I (ANI)		AOTA DOO45	0.05	0.40	0.40	0.00

Acid Number (AN)

0.12

0.10

mg KOH/g ASTM D8045 0.05

0.09



## **OIL ANALYSIS REPORT**





Certificate L2367

Lab Number **Unique Number** 

: 06027769 Test Package : IND 2

: 10777560

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: 08 Dec 2023 Diagnosed Diagnostician : Doug Bogart

DAVENPORT, IA US 52802 Contact: JOHN KONRAD

john.konrad@kraftheinz.com

T:

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (563)326-8391