


OIL ANALYSIS REPORT

Sample Rating Trend







Machine Id L7
Component Pump
Fluid

USPI VAC 100 (--- LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Jun2021 Jun2021 Dec2021 Jun2022 Dec2022 May2023 Nov2023						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM31949	USPM29395	USPM28423
Sample Date		Client Info		29 Nov 2023	18 Aug 2023	22 May 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	<1	<1	<1
Chromium	ppm	ASTM D5185m	>5	<1	0	<1
Nickel	ppm	ASTM D5185m	>5	0	0	<1
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>7	0	0	0
Lead	ppm	ASTM D5185m	>12	0	0	<1
Copper	ppm	ASTM D5185m	>30	0	0	0
Tin	ppm	ASTM D5185m	>9	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<1	0	2
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	0	0	<1	0
Calcium	ppm	ASTM D5185m	0	0	2	0
Phosphorus	ppm	ASTM D5185m	1800	1336	1430	1426
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	0	22	78	46
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	18	17	11
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	1	0	2
Water	%	ASTM D6304	>.1	0.050	0.057	0.046
ppm Water	ppm	ASTM D6304	>1000	507	574.4	463.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	36	279	167
Particles >6µm		ASTM D7647	>2500	17	98	55
Particles >14μm		ASTM D7647	>640	5	22	12
Particles >21µm		ASTM D7647	>160	1	7	5
Particles >38µm		ASTM D7647	>40	0	0	0
Particles >71µm		ASTM D7647	>10	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/16	12/11/10	15/14/12	15/13/11
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
A si al Niversala a v. (ANI)	I/OII/-	ACTM DODAE	0.05	0.10	0.11	0.40

Acid Number (AN)

0.11

0.12

mg KOH/g ASTM D8045 0.05

0.10



OIL ANALYSIS REPORT







Certificate L2367

Lab Number **Unique Number**

Test Package

: 06027773 : 10777564

Diagnosed

: 08 Dec 2023 Diagnostician : Doug Bogart

DAVENPORT, IA US 52802

F: (563)326-8391

Contact: JOHN KONRAD john.konrad@kraftheinz.com

T:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: IND 2

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: JOHN KONRAD - KRADAV