

# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



# KAESER 1625157 - YANFENG (S/N 1025)

Compressor

KAESER SIGMA (OEM) S-460 (15 GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

w2010 May2011 Jui2014 Maz2016 Jan2018 Feb.2018 Maz2020 Jun2022							
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		WC0863731	WC0795159	WC0679532	
Sample Date		Client Info		09 Nov 2023	23 May 2023	07 Sep 2022	
Machine Age	hrs	Client Info		10640	0	100630	
Oil Age	hrs	Client Info		1	0	1341	
Oil Changed		Client Info		Not Changd	Changed	Changed	
Sample Status				NORMAL	NORMAL	NORMAL	
CONTAMINATION		method	limit/base	current	history1	history2	
Water		WC Method	>0.05	NEG	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	0	0	2	
Chromium	ppm	ASTM D5185m	>10	0	0	<1	
Nickel	ppm	ASTM D5185m	>3	0	<1	0	
Titanium	ppm	ASTM D5185m	>3	0	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	<1	
Aluminum	ppm	ASTM D5185m	>10	0	0	2	
Lead	ppm	ASTM D5185m	>10	0	0	0	
Copper	ppm	ASTM D5185m	>50	<1	<1	<1	
Tin	ppm	ASTM D5185m	>10	0	0	<1	
Vanadium	ppm	ASTM D5185m		0	0	<1	
Cadmium	ppm	ASTM D5185m		0	0	<1	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0	<1	
Barium	ppm	ASTM D5185m	90	61	64	0	
Molybdenum	ppm	ASTM D5185m		0	0	0	
Manganese	ppm	ASTM D5185m		<1	0	<1	
Magnesium	ppm	ASTM D5185m	90	78	83	73	
Calcium	ppm	ASTM D5185m	2	<1	1	1	
Phosphorus	ppm	ASTM D5185m		3	2	2	
Zinc	ppm	ASTM D5185m		0	<1	8	
Sulfur	ppm	ASTM D5185m		18493	19495	18054	
CONTAMINANTS	;	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	0	0	<1	
Sodium	ppm	ASTM D5185m		4	0	11	
Potassium	ppm	ASTM D5185m	>20	0	2	3	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	

Acid Number (AN)

mg KOH/g ASTM D8045 0.4


0.36


0.36

0.40



## **OIL ANALYSIS REPORT**





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2

I LOID I HOI LITTILO							
Visc @ 40°C	cSt	ASTM D445	46	44.0	44.1	43.6	


SAMPLE IMAGES








Color

**Bottom** 













Certificate L2367

Laboratory Sample No. Lab Number Unique Number : 10777624

: WC0863731 : 06027833 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 07 Dec 2023 Diagnosed

: 09 Dec 2023 Diagnostician : Don Baldridge **ELEVATED INDUSTRIAL SOLUTIONS - EIS** 

302 HUGHES ST FOUNTAIN INN, SC US 29644

Contact: DARRIN WARD dward@elevatedindustrial.com

Contact/Location: DARRIN WARD - PALFOU

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (864)862-7653

T: