




PROBLEM SUMMARY

Sample Rating Trend



WATER



Machine Id
KAESER 8341485 - SNIDER TIRE (S/N 1179)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (2 GAL)

COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

We advise that you follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	SEVERE	ABNORMAL
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ HAZY	NORML	▲ HAZY
Free Water	scalar	*Visual		▲ 1.0	10.0	NEG

Customer Id: PALFOU
Sample No.: WC0863520
Lab Number: 06027865
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

10 Aug 2023 Diag: Don Baldrige

WATER



We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a light concentration of water present in the oil. Excessive free water present. The AN level is acceptable for this fluid.

[view report](#)



10 Jan 2023 Diag: Don Baldrige

WATER



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. Appearance is hazy. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

[view report](#)



10 Nov 2022 Diag: Angela Borella

WATER



We advise that you follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. All component wear rates are normal. Appearance is unacceptable. There is a light concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
KAESER 8341485 - SNIDER TIRE (S/N 1179)

Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (2 GAL)

DIAGNOSIS

▲ Recommendation

We advise that you follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

▲ Contamination

Appearance is hazy. Free water present. There is a moderate amount of visible silt present in the sample.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0863520	WC0825913	WC0763766
Sample Date	Client Info		15 Nov 2023	10 Aug 2023	10 Jan 2023
Machine Age	hrs	Client Info	2148	1965	1513
Oil Age	hrs	Client Info	2148	226	1513
Oil Changed	Client Info		N/A	Not Changd	Not Changd
Sample Status			ABNORMAL	SEVERE	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	0	<1	0
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m >3	0	0	0
Titanium	ppm	ASTM D5185m >3	0	0	0
Silver	ppm	ASTM D5185m >2	0	0	0
Aluminum	ppm	ASTM D5185m >10	0	0	0
Lead	ppm	ASTM D5185m >10	0	0	1
Copper	ppm	ASTM D5185m >50	12	2	14
Tin	ppm	ASTM D5185m >10	0	0	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m 90	0	<1	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	0	<1
Magnesium	ppm	ASTM D5185m 90	27	39	16
Calcium	ppm	ASTM D5185m 2	1	<1	<1
Phosphorus	ppm	ASTM D5185m	3	5	2
Zinc	ppm	ASTM D5185m	12	5	10
Sulfur	ppm	ASTM D5185m	18203	20955	21170

CONTAMINANTS




	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	0	0	<1
Sodium	ppm	ASTM D5185m	7	4	8
Potassium	ppm	ASTM D5185m >20	2	<1	0
Water	%	ASTM D6304 >0.05	0.039	▲ 0.697	▲ 0.122
ppm Water	ppm	ASTM D6304 >500	390	▲ 6970	▲ 1220

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	0.23	0.30	0.29




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ HAZY	NORML	▲ HAZY
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	▲ 0.2%	0.2%
Free Water	scalar	*Visual		▲ 1.0	■ 10.0	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.0	43.7	49.9

SAMPLE IMAGES



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0863520 **Received** : 07 Dec 2023
Lab Number : **06027865** **Diagnosed** : 09 Dec 2023
Unique Number : 10777656 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF)

ELEVATED INDUSTRIAL SOLUTIONS - EIS
 302 HUGHES ST
 FOUNTAIN INN, SC
 US 29644
 Contact: DARRIN WARD
 dward@elevatedindustrial.com
 T:
 F: (864)862-7653

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)