


OIL ANALYSIS REPORT

CFG-546 [PM6-3135623] Machine Id QUINCY 98629H - MISSION BELL WINERY

Component

Compressor





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jui2021 Dec2021 Jui2022 Feb2023 Nov2023					
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		UCH06027882	UCH05791046	UCH05599563	
Sample Date		Client Info		10 Nov 2023	21 Feb 2023	11 Jul 2022	
Machine Age	hrs	Client Info		66645	63027	59112	
Oil Age	hrs	Client Info		0	3915	7605	
Oil Changed		Client Info		Changed	Not Changd	Changed	
Sample Status				NORMAL	NORMAL	NORMAL	
CONTAMINATIO	V	method	limit/base	current	history1	history2	
Water		WC Method	>0.1	NEG	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	0	0	0	
Chromium	ppm	ASTM D5185m		0	0	0	
Nickel	ppm	ASTM D5185m		0	<1	0	
Titanium	ppm	ASTM D5185m		0	0	0	
Silver	ppm	ASTM D5185m		0	0	0	
Aluminum	ppm	ASTM D5185m	>25	0	<1	<1	
Lead	ppm	ASTM D5185m	>25	0	0	<1	
Copper	ppm	ASTM D5185m	>50	<1	<1	<1	
Tin	ppm	ASTM D5185m	>15	0	0	0	
Antimony	ppm	ASTM D5185m	7.0				
Vanadium	ppm	ASTM D5185m		0	0	0	
Cadmium	ppm	ASTM D5185m		0	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	0	0	
Barium	ppm	ASTM D5185m	0	0	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	0	
Manganese	ppm	ASTM D5185m	0	<1	0	0	
Magnesium	ppm	ASTM D5185m	1.2	0	0	0	
Calcium	ppm	ASTM D5185m	0	0	0	0	
Phosphorus	ppm	ASTM D5185m	295	70	9	63	
Zinc	ppm	ASTM D5185m	0	0	0	0	
Sulfur	ppm	ASTM D5185m	253	587	652	283	
CONTAMINANTS	;	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	0	0	<1	
Sodium	ppm	ASTM D5185m		2	0	0	
Potassium	ppm	ASTM D5185m	>20	0	<1	<1	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.252	0.26	0.25	0.81	



OIL ANALYSIS REPORT




VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	47.16	45.8	45.1	47.9


Color


SAMPLE IMAGES


















Laboratory

Sample No. Lab Number **Unique Number**

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCH06027882 : 06027882 : 10777673

Received Diagnosed

: 07 Dec 2023 : 09 Dec 2023 Diagnostician : Don Baldridge

CISCO AIR SYSTEMS 214 27TH ST SACRAMENTO, CA US 95816 Contact: BARRY FRKOVICH

barryfrkovich@ciscoair.com T: (916)444-2525

F: x:

Test Package : IND 2 Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)