


PROBLEM SUMMARY

Sample Rating Trend




DEGRADATION




Area
COOLING TOWER
Machine Id
COOLING TOWER NORTH FAN (S/N F601GB)
Component
Gearbox
Fluid
SCHAEFFER 209 MOLY UNIVERSAL GEARLUBE ISO 220 (6 GAL)

COMPONENT CONDITION SUMMARY

▲ Acid Number



▲ Particle Trend



RECOMMENDATION

Oil was changed based on visual and fluid health indicators. Confirm oil type as additive and Acid number indicators indicate a change in oil type. No other action required at this time. Resample at next normal interval.

PROBLEMATIC TEST RESULTS

| Sample Status | | | ABNORMAL | ABNORMAL | ABNORMAL |
|------------------|--------------|----------------|-------------------|------------|------------|
| Particles >4µm | ASTM D7647 | >20000 | ▲ 68004 | ▲ 112312 | ▲ 124832 |
| Particles >6µm | ASTM D7647 | >5000 | ▲ 11844 | ▲ 6564 | ▲ 8639 |
| Oil Cleanliness | ISO 4406 (c) | >21/19/16 | ▲ 23/21/15 | ▲ 24/20/14 | ▲ 24/20/14 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 2.5 | ▲ 0.92 | 2.44 | 2.39 |

Customer Id: HEXDIB
Sample No.: PLS0000655
Lab Number: 06028589
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Mike Johnson +1 (615)771-6030
mike.johnson@amrri.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

14 Dec 2022 Diag: Mike Johnson

WEAR



Filter oil if possible using B6=75 filter media or better. No other action required at this time. Resample at next normal interval. Wear particles are notable but steady. Contamination is exceptionally elevated. Filtration will help to extend machine life. Fluid health is acceptable for continued use.

view report



23 Mar 2022 Diag: Mike Johnson

ISO



Filter the oil if possible using B6=75 media. Please contact Mike Johnson for additional support if you wish to pursue this option. We will scrutinize the FTIR Oxidation values moving forward. No other corrective action at this time. The wear rate is moderate and steady. The ISO cleanliness values are elevated. Filter if possible. Fluid health parameters suggest that we should scrutinize oxidation values moving forward, and be prepared to make a sump change if there is continued rise. TAN is a lagging indicator of change, and will be a secondary consideration.

view report



14 Dec 2021 Diag: Mike Johnson

ISO




Filter with B6=75 filter media or better if possible. If filtering is not possible, resample immediately to confirm levels and consider oil change if sample is consistent. Wear particles are low and acceptable. Particulate contamination is substantially elevated, which can reduce longevity of the machine. Fluid health is acceptable for continued use.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Area
COOLING TOWER
Machine Id
COOLING TOWER NORTH FAN (S/N F601GB)
Component
Gearbox
Fluid
SCHAEFFER 209 MOLY UNIVERSAL GEARLUBE ISO 220 (6 GAL)

DIAGNOSIS

Recommendation

Oil was changed based on visual and fluid health indicators. Confirm oil type as additive and Acid number indicators indicate a change in oil type. No other action required at this time. Resample at next normal interval.

Wear

Wear particles are low and improved from previous samples.

Contamination

Contamination is elevated. Filtration can help to extend machine life.

Fluid Condition

Fluid health is acceptable for continued use.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | PLS0000655 | PLS0000422 | PLS0000415 |
| Sample Date | Client Info | | 06 Dec 2023 | 14 Dec 2022 | 23 Mar 2022 |
| Machine Age | yrs | Client Info | 0 | 8 | 8 |
| Oil Age | yrs | Client Info | 0 | 2 | 5 |
| Oil Changed | Client Info | | N/A | N/A | N/A |
| Sample Status | | | ABNORMAL | ABNORMAL | ABNORMAL |

CONTAMINATION

| | method | limit/base | current | history1 | history2 |
|-------|-----------|------------|------------|----------|----------|
| Water | WC Method | >0.2 | NEG | NEG | NEG |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|------------|------------------|--------------|----------|----------|
| PQ | ASTM D8184 | | 16 | 23 | 28 |
| Iron | ppm | ASTM D5185m >200 | 9 | ▲ 64 | 58 |
| Chromium | ppm | ASTM D5185m >15 | 0 | <1 | <1 |
| Nickel | ppm | ASTM D5185m >15 | <1 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | 0 | 1 | 0 |
| Aluminum | ppm | ASTM D5185m >25 | 2 | 2 | 1 |
| Lead | ppm | ASTM D5185m >100 | 3 | <1 | <1 |
| Copper | ppm | ASTM D5185m >200 | <1 | <1 | <1 |
| Tin | ppm | ASTM D5185m >25 | 0 | 0 | 0 |
| Antimony | ppm | ASTM D5185m >5 | --- | --- | --- |
| Vanadium | ppm | ASTM D5185m | 0 | <1 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|-------------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m 65 | 12 | 88 | 85 |
| Barium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m 325 | 190 | 343 | 344 |
| Manganese | ppm | ASTM D5185m | <1 | 1 | 1 |
| Magnesium | ppm | ASTM D5185m | 2 | 3 | 6 |
| Calcium | ppm | ASTM D5185m | 4 | 55 | 86 |
| Phosphorus | ppm | ASTM D5185m 875 | 636 | 908 | 874 |
| Zinc | ppm | ASTM D5185m | 552 | 99 | 103 |
| Sulfur | ppm | ASTM D5185m 16000 | 14954 | 19771 | 14889 |






CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|-----------------|----------|----------|----------|
| Silicon | ppm | ASTM D5185m >50 | 4 | 8 | 6 |
| Sodium | ppm | ASTM D5185m | 4 | 5 | 5 |
| Potassium | ppm | ASTM D5185m >20 | 2 | 8 | 5 |

INFRA-RED

| | method | limit/base | current | history1 | history2 |
|-----------|---------|-------------|-------------|----------|----------|
| Soot % | % | *ASTM D7844 | 0 | 0.1 | 0.1 |
| Nitration | Abs/cm | *ASTM D7624 | 4.0 | 4.7 | 4.7 |
| Sulfation | Abs:1mm | *ASTM D7415 | 13.0 | 17.9 | 17.3 |

OIL ANALYSIS REPORT




| FLUID CLEANLINESS | method | limit/base | current | history1 | history2 |
|-------------------|--------------|------------|-------------------|------------|------------|
| Particles >4µm | ASTM D7647 | >20000 | ▲ 68004 | ▲ 112312 | ▲ 124832 |
| Particles >6µm | ASTM D7647 | >5000 | ▲ 11844 | ▲ 6564 | ▲ 8639 |
| Particles >14µm | ASTM D7647 | >640 | 250 | 97 | 122 |
| Particles >21µm | ASTM D7647 | >160 | 29 | 19 | 27 |
| Particles >38µm | ASTM D7647 | >40 | 0 | 1 | 4 |
| Particles >71µm | ASTM D7647 | >10 | 0 | 1 | 1 |
| Oil Cleanliness | ISO 4406 (c) | >21/19/16 | ▲ 23/21/15 | ▲ 24/20/14 | ▲ 24/20/14 |

| FLUID DEGRADATION | method | limit/base | current | history1 | history2 |
|-------------------|----------------------|------------|---------------|----------|----------|
| Oxidation | Abs/.1mm *ASTM D7414 | | 3.8 | 6.3 | 6.1 |
| Acid Number (AN) | mg KOH/g ASTM D8045 | 2.5 | ▲ 0.92 | 2.44 | 2.39 |

| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|----------------|------------|--------------|----------|----------|
| White Metal | scalar *Visual | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar *Visual | NONE | NONE | NONE | NONE |
| Sand/Dirt | scalar *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar *Visual | >0.2 | NEG | NEG | NEG |
| Free Water | scalar *Visual | | NEG | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|---------------|------------|------------|----------|----------|
| Visc @ 40°C | cSt ASTM D445 | 219 | 212 | 223 | 223 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PLS0000655 **Received** : 07 Dec 2023
Lab Number : **06028589** **Diagnosed** : 15 Dec 2023
Unique Number : 10778380 **Diagnostician** : Mike Johnson
Test Package : IND 2 (Additional Tests: FT-IR, PQ, PrtCount)

HEXION - DIBOLL PLANT
 100 W BORDEN DR
 DIBOLL, TX
 US 75941
 Contact: DENISE ROBERTSON
 denise.robertson@hexion.com;mike.johnson@amrri.com
 T: (936)829-8029
 F: (936)829-8003

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)