


# PROBLEM SUMMARY

Area  
**COOLING TOWER**  
Machine Id  
**COOLING TOWER SOUTH FAN (S/N G602GB)**  
Component  
**Gearbox**  
Fluid  
**SCHAEFFER 209 MOLY UNIVERSAL GEARLUBE ISO 220 (6 GAL)**

Sample Rating Trend




## ADDITIVES




### COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Additives



### RECOMMENDATION

Oil contamination is slightly elevated. Wear is normal and low. Confirm oil type as additives are different from previous samples. No other action required at this time. Resample at next normal interval.

### PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	SEVERE
Boron	ppm	ASTM D5185m	65	▲ 8	▲ 4	78
Phosphorus	ppm	ASTM D5185m	875	▲ 560	▲ 499	1172
Sulfur	ppm	ASTM D5185m	16000	▲ 13837	▲ 14835	27520
Particles >4µm		ASTM D7647	>20000	▲ 48699	5053	● 182108
Particles >6µm		ASTM D7647	>5000	▲ 6838	1498	● 49900
Oil Cleanliness		ISO 4406 (c)	>21/19/16	▲ 23/20/15	20/18/14	● 25/23/16

Customer Id: HEXDIB  
Sample No.: PLS0000656  
Lab Number: 06028591  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Mike Johnson +1 (615)771-6030  
[mike.johnson@amrri.com](mailto:mike.johnson@amrri.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

There are no recommended actions for this sample.

## HISTORICAL DIAGNOSIS

### 23 Aug 2023 Diag: Mike Johnson

#### ADDITIVES



Oil condition is on par with new unfiltered oil. Confirm oil type as additives are different from previous samples. No other action required at this time. Resample at next normal interval. Wear rates are low and much improved from previous samples. Particulate contamination is on par with new unfiltered oil and much improved from previous samples. Filtration can help extend machine life. Fluid additives are slightly lower than expected but health indicators such as oxidation and acid number are much improved from previous samples. Verification of the oil used should clarify the additives discrepancy.

view report



### 14 Dec 2022 Diag: Mike Johnson

#### WEAR



Wear is accelerating and contamination is significantly elevated, necessitating immediate filtration action or oil change. Resample after 1 month of running after the filter or oil change action has been taken. Consider using other predictive maintenance techniques to confirm the wear (vibration, machine load). Iron particles are substantially elevated from previous samples. Particle contamination is critically elevated and necessitates some action to preserve the machinery. Fluid health is acceptable for continued use provided that contamination is brought under control.

view report



### 14 Dec 2021 Diag: Mike Johnson

#### WEAR




Investigate machine for other possible signs of wear (vibration, slop in gears, excessive heat). Resample at next normal interval. Iron wear particles are substantially elevated indicating a rapid rate of wear. This is likely caused by elevated particle contamination over extended periods of time. Particle contamination is on par with new unfiltered oil. Oil health is acceptable for continued use.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



## ADDITIVES



Area  
**COOLING TOWER**  
Machine Id  
**COOLING TOWER SOUTH FAN (S/N G602GB)**  
Component  
**Gearbox**  
Fluid  
**SCHAEFFER 209 MOLY UNIVERSAL GEARLUBE ISO 220 (6 GAL)**

### DIAGNOSIS

#### Recommendation

Oil contamination is slightly elevated. Wear is normal and low. Confirm oil type as additives are different from previous samples. No other action required at this time. Resample at next normal interval.

#### Wear

Wear rates are low and much improved from previous samples.

#### Contamination

Particulate contamination is slightly elevated.

#### Fluid Condition

Fluid additives are slightly lower than expected but health indicators such as oxidation and acid number are much improved from previous samples. Verification of the oil used should clarify the additives discrepancy.

### SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PLS0000656</b>	PLS0000651	PLS0000423
Sample Date	Client Info	<b>06 Dec 2023</b>	23 Aug 2023	14 Dec 2022
Machine Age	days	<b>0</b>	1	7
Oil Age	days	<b>0</b>	1	2
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	SEVERE

### CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.2	<b>NEG</b>	NEG	NEG

### WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184	<b>13</b>	14	35
Iron	ppm ASTM D5185m >200	<b>3</b>	<1	354
Chromium	ppm ASTM D5185m >15	<b>0</b>	0	2
Nickel	ppm ASTM D5185m >15	<b>0</b>	0	<1
Titanium	ppm ASTM D5185m	<b>0</b>	0	<1
Silver	ppm ASTM D5185m	<b>0</b>	<1	1
Aluminum	ppm ASTM D5185m >25	<b>2</b>	3	4
Lead	ppm ASTM D5185m >100	<b>0</b>	0	1
Copper	ppm ASTM D5185m >200	<b>&lt;1</b>	0	1
Tin	ppm ASTM D5185m >25	<b>0</b>	0	0
Antimony	ppm ASTM D5185m >5	<b>---</b>	---	---
Vanadium	ppm ASTM D5185m	<b>0</b>	0	<1
Cadmium	ppm ASTM D5185m	<b>0</b>	0	0

### ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 65	<b>▲ 8</b>	▲ 4	78
Barium	ppm ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm ASTM D5185m 325	<b>141</b>	164	377
Manganese	ppm ASTM D5185m	<b>&lt;1</b>	0	4
Magnesium	ppm ASTM D5185m	<b>&lt;1</b>	4	18
Calcium	ppm ASTM D5185m	<b>&lt;1</b>	5	87
Phosphorus	ppm ASTM D5185m 875	<b>▲ 560</b>	▲ 499	1172
Zinc	ppm ASTM D5185m	<b>398</b>	27	129
Sulfur	ppm ASTM D5185m 16000	<b>▲ 13837</b>	▲ 14835	27520






### CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >50	<b>3</b>	3	12
Sodium	ppm ASTM D5185m	<b>2</b>	9	2
Potassium	ppm ASTM D5185m >20	<b>1</b>	0	3

### INFRA-RED

method	limit/base	current	history1	history2
Soot %	% *ASTM D7844	<b>0</b>	0	0.1
Nitration	Abs/cm *ASTM D7624	<b>4.0</b>	4.0	5.0
Sulfation	Abs:1mm *ASTM D7415	<b>12.0</b>	11.5	17.6

# OIL ANALYSIS REPORT




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 48699	5053	● 182108
Particles >6µm	ASTM D7647	>5000	▲ 6838	1498	● 49900
Particles >14µm	ASTM D7647	>640	272	144	536
Particles >21µm	ASTM D7647	>160	51	39	74
Particles >38µm	ASTM D7647	>40	1	1	6
Particles >71µm	ASTM D7647	>10	0	0	2
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 23/20/15	20/18/14	● 25/23/16

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414		3.5	3.4	6.2
Acid Number (AN)	mg KOH/g ASTM D8045	2.5	0.74	0.96	2.91

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar *Visual	NONE	NONE	NONE	NONE
Precipitate	scalar *Visual	NONE	NONE	NONE	NONE
Silt	scalar *Visual	NONE	NONE	NONE	NONE
Debris	scalar *Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar *Visual	NONE	NONE	NONE	NONE
Appearance	scalar *Visual	NORML	NORML	NORML	NORML
Odor	scalar *Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar *Visual	>0.2	NEG	NEG	NEG
Free Water	scalar *Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D445	219	209	207	232

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PLS0000656 **Received** : 07 Dec 2023  
**Lab Number** : 06028591 **Diagnosed** : 15 Dec 2023  
**Unique Number** : 10778382 **Diagnostician** : Mike Johnson  
**Test Package** : IND 2 ( Additional Tests: FT-IR, PQ, PrtCount )

**HEXION - DIBOLL PLANT**  
 100 W BORDEN DR  
 DIBOLL, TX  
 US 75941  
 Contact: DENISE ROBERTSON  
 denise.robertson@hexion.com;mike.johnson@amrri.com  
 T: (936)829-8029  
 F: (936)829-8003

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)