


# PROBLEM SUMMARY

Sample Rating Trend




**DEGRADATION**




Area  
**COOLING TOWER**  
Machine Id  
**Motor - EAST COOLING TOWER PUMP (S/N P611M)**  
Component  
**Bearing**  
Fluid  
**TURBINE OIL ISO 32 (6 QTS)**

## COMPONENT CONDITION SUMMARY

▲ Acid Number



▲ Additives



## RECOMMENDATION

Oil profile is not complete. Please provide a reference for oil type in use and confirm that correct oil is in use in the machine. Trends are constant against previously gathered samples. Resample at next normal interval.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL
Molybdenum	ppm	ASTM D5185m	5	▲ 217	▲ 224	▲ 231
Phosphorus	ppm	ASTM D5185m	275	▲ 506	▲ 470	▲ 497
Zinc	ppm	ASTM D5185m	7	▲ 461	▲ 450	▲ 439
Sulfur	ppm	ASTM D5185m	400	▲ 1628	▲ 1560	▲ 1455
Acid Number (AN)	mg KOH/g	ASTM D8045	0.13	▲ 0.74	▲ 0.83	▲ 0.875

Customer Id: HEXDIB  
Sample No.: PLS0000653  
Lab Number: 06028592  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Mike Johnson +1 (615)771-6030  
[mike.johnson@amrri.com](mailto:mike.johnson@amrri.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 20 Dec 2022 Diag: Mike Johnson

#### DEGRADATION



Oil profile is not complete. Please provide a reference for oil type in use and confirm that correct oil is in use in the machine. Trends are constant against previously gathered samples. Resample at next normal interval. Wear particles are low and acceptable. Contamination is on par with new unfiltered oil. Fluid health indicators do not match the oil profile on file.

view report



### 14 Dec 2021 Diag: Mike Johnson

#### DEGRADATION



Confirm the oil used in this machine. Oil additive profile in the sample does not match the oil on file. Additives and health are consistent with previous sampling. Resample at next normal interval and confirm oil product on next sample label. Wear particles are low and acceptable. Contamination is low and acceptable. Oil profile does not match the reference oil on file. More correct analysis can be obtained if a reference oil is correctly identified. Fluid appears to be unchanging from previous two samples.

view report



### 09 Dec 2020 Diag: Mike Johnson

#### DEGRADATION




Please investigate the type of oil used in this sump. The additives are not typical for Turbine Oil, but are characteristic of EP and AW oil. The AN values reinforce that there is AW/EP chemistry in the sump. The viscosity is correct, so there is no urgent need to change the oil to address this. Wear values are all low and steady. The contaminant load is moderate for a journal bearing. Continue to monitor. The fluid is not corrupted. It may be a blend of various product types, which will lead to questionable performance, but there is no urgent need to make an oil change. Continue to monitor.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



**DEGRADATION**



Area  
**COOLING TOWER**  
Machine Id  
**Motor - EAST COOLING TOWER PUMP (S/N P611M)**  
Component  
**Bearing**  
Fluid  
**TURBINE OIL ISO 32 (6 QTS)**

**DIAGNOSIS**

**Recommendation**

Oil profile is not complete. Please provide a reference for oil type in use and confirm that correct oil is in use in the machine. Trends are constant against previously gathered samples. Resample at next normal interval.

**Wear**

Wear particles are low and acceptable.

**Contamination**

Contamination is on par with new unfiltered oil.

**Fluid Condition**

Fluid health indicators do not match the oil profile on file.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>PLS0000653</b>	PLS0000424	PLS0000235
Sample Date	Client Info			<b>06 Dec 2023</b>	20 Dec 2022	14 Dec 2021
Machine Age	yrs	Client Info		<b>0</b>	5	2
Oil Age	yrs	Client Info		<b>0</b>	6	5
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>2	<b>NEG</b>	NEG	NEG






WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		<b>14</b>	6	14
Iron	ppm	ASTM D5185m	>20	<b>0</b>	2	2
Chromium	ppm	ASTM D5185m	>20	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	>20	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>20	<b>2</b>	0	0
Lead	ppm	ASTM D5185m	>20	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185m	>20	<b>8</b>	6	4
Tin	ppm	ASTM D5185m	>20	<b>0</b>	0	0
Antimony	ppm	ASTM D5185m		<b>---</b>	---	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	<b>5</b>	0	2
Barium	ppm	ASTM D5185m	5	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	5	<b>▲ 217</b>	▲ 224	▲ 231
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	<1
Magnesium	ppm	ASTM D5185m	5	<b>&lt;1</b>	0	0
Calcium	ppm	ASTM D5185m	10	<b>2</b>	5	4
Phosphorus	ppm	ASTM D5185m	275	<b>▲ 506</b>	▲ 470	▲ 497
Zinc	ppm	ASTM D5185m	7	<b>▲ 461</b>	▲ 450	▲ 439
Sulfur	ppm	ASTM D5185m	400	<b>▲ 1628</b>	▲ 1560	▲ 1455

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<b>2</b>	2	2
Sodium	ppm	ASTM D5185m		<b>2</b>	0	2
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	<1	0

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		<b>0</b>	0	0
Nitration	Abs/cm	*ASTM D7624		<b>1.9</b>	2.2	2.1
Sulfation	Abs:1mm	*ASTM D7415		<b>10.8</b>	10.9	11.1

# OIL ANALYSIS REPORT




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	<b>1256</b>	2542	1513
Particles >6µm	ASTM D7647	>2500	<b>175</b>	403	176
Particles >14µm	ASTM D7647	>160	<b>8</b>	20	10
Particles >21µm	ASTM D7647	>40	<b>1</b>	4	2
Particles >38µm	ASTM D7647	>10	<b>0</b>	0	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/14	<b>17/15/10</b>	19/16/11	18/15/10

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414		<b>2.2</b>	2.3	2.2
Acid Number (AN)	mg KOH/g ASTM D8045	0.13	<b>▲ 0.74</b>	▲ 0.83	▲ 0.875

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar *Visual	NONE	<b>NONE</b>	VLITE	NONE
Sand/Dirt	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar *Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar *Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar *Visual	>2	<b>NEG</b>	NEG	NEG
Free Water	scalar *Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D445	32	<b>34.0</b>	34.1	34.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



Color

Bottom



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PLS0000653 **Received** : 07 Dec 2023  
**Lab Number** : **06028592** **Diagnosed** : 15 Dec 2023  
**Unique Number** : 10778383 **Diagnostician** : Mike Johnson  
**Test Package** : IND 2 ( Additional Tests: FT-IR, PQ, PrtCount )

**HEXION - DIBOLL PLANT**  
 100 W BORDEN DR  
 DIBOLL, TX  
 US 75941  
 Contact: DENISE ROBERTSON  
 denise.robertson@hexion.com;mike.johnson@amrri.com  
 T: (936)829-8029  
 F: (936)829-8003

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)