


PROBLEM SUMMARY

Sample Rating Trend




DEGRADATION




Area
COOLING TOWER
Machine Id
Motor - MIDDLE COOLING TOWER PUMP (S/N P612M)
Component
Bearing
Fluid
TURBINE OIL ISO 32 (6 QTS)

COMPONENT CONDITION SUMMARY


▲ Acid Number



▲ Non-ferrous Metals



▲ Additives



RECOMMENDATION

Oil profile does not match the reference oil on file. Please provide a reference oil sample for the lab to test against. No other action required at this time. Resample at next normal interval.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Copper	ppm	ASTM D5185m	>20	▲ 32	▲ 25	▲ 21
Molybdenum	ppm	ASTM D5185m	5	▲ 235	▲ 239	240
Phosphorus	ppm	ASTM D5185m	275	▲ 549	▲ 523	542
Zinc	ppm	ASTM D5185m	7	▲ 556	▲ 528	511
Sulfur	ppm	ASTM D5185m	400	▲ 1798	▲ 1899	1621
Acid Number (AN)	mg KOH/g	ASTM D8045	0.13	▲ 0.83	▲ 1.01	▲ 1.005

Customer Id: HEXDIB
Sample No.: PLS0000652
Lab Number: 06028593
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Mike Johnson +1 (615)771-6030
mike.johnson@amrri.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

20 Dec 2022 Diag: Mike Johnson

DEGRADATION



Oil profile does not match the reference oil on file. Please provide a reference oil sample for the lab to test against. No other action required at this time. Resample at next normal interval. Copper wear particles are steadily rising. Investigate possible sources of copper wear. Contamination is low and acceptable. Fluid health indicators are steady when compared with previous samples, but can be verified with a reference sample on file.

view report



14 Dec 2021 Diag: Mike Johnson

DEGRADATION



Confirm that reference oil is correct. The additive profile does not match the oil on file, but are consistent with previous samples. Resample at next normal interval and indicate exact oil used on label. Investigate possible copper sources for wear. Copper levels are indicating a slight increase from previous samples. Other wear indicators are low and acceptable. Particle contamination is low and acceptable. Fluid additives are not consistent with reference oil on file. Additives are consistent with previous sampling. Acid number is marginally increased from previous sample.

view report



05 Feb 2021 Diag: Mike Johnson

NORMAL



No further action required. This was the second sample pulled on the pump. The only notable difference is the Particle Count, which is substantially lower than the other sample.


Wear debris was collected for photographs from the sample containing the higher particle count. No change in status. No change in status. No change in status.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Area
COOLING TOWER
Machine Id
Motor - MIDDLE COOLING TOWER PUMP (S/N P612M)
Component
Bearing
Fluid
TURBINE OIL ISO 32 (6 QTS)

DIAGNOSIS

Recommendation

Oil profile does not match the reference oil on file. Please provide a reference oil sample for the lab to test against. No other action required at this time. Resample at next normal interval.

Wear

Copper wear particles are steadily rising. Investigate possible sources of copper wear.

Contamination

Contamination is low and acceptable.

Fluid Condition

Fluid health indicators are steady when compared with previous samples, but can be verified with a reference sample on file.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PLS0000652	PLS0000425	PLS0000234
Sample Date	Client Info		06 Dec 2023	20 Dec 2022	14 Dec 2021
Machine Age	yrs	Client Info	0	9	8
Oil Age	yrs	Client Info	0	5	4
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>2	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		16	11	17
Iron	ppm	ASTM D5185m >20	0	3	2
Chromium	ppm	ASTM D5185m >20	0	0	0
Nickel	ppm	ASTM D5185m >20	0	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >20	2	0	0
Lead	ppm	ASTM D5185m >20	0	<1	<1
Copper	ppm	ASTM D5185m >20	▲ 32	▲ 25	▲ 21
Tin	ppm	ASTM D5185m >20	0	0	0
Antimony	ppm	ASTM D5185m	---	---	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 5	6	0	2
Barium	ppm	ASTM D5185m 5	0	0	0
Molybdenum	ppm	ASTM D5185m 5	▲ 235	▲ 239	240
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m 5	<1	<1	0
Calcium	ppm	ASTM D5185m 10	20	20	20
Phosphorus	ppm	ASTM D5185m 275	▲ 549	▲ 523	542
Zinc	ppm	ASTM D5185m 7	▲ 556	▲ 528	511
Sulfur	ppm	ASTM D5185m 400	▲ 1798	▲ 1899	1621

CONTAMINANTS


	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	11	9	7
Sodium	ppm	ASTM D5185m	4	<1	3
Potassium	ppm	ASTM D5185m >20	<1	1	0

INFRA-RED


	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0	0
Nitration	Abs/cm	*ASTM D7624	2.0	2.3	2.2
Sulfation	Abs:1mm	*ASTM D7415	11.1	11.1	11.4

OIL ANALYSIS REPORT


▲ Acid Number




▲ Non-ferrous Metals




▲ Additives



Particle Count



Viscosity @ 40°C




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	2234	2534	1274
Particles >6µm	ASTM D7647	>2500	305	196	153
Particles >14µm	ASTM D7647	>160	12	7	9
Particles >21µm	ASTM D7647	>40	2	1	0
Particles >38µm	ASTM D7647	>10	0	0	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/14	18/15/11	19/15/10	17/14/10

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm *ASTM D7414		2.3	2.3	2.2
Acid Number (AN)	mg KOH/g ASTM D8045	0.13	▲ 0.83	▲ 1.01	▲ 1.005

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar *Visual	NONE	NONE	NONE	NONE
Precipitate	scalar *Visual	NONE	NONE	NONE	NONE
Silt	scalar *Visual	NONE	NONE	NONE	NONE
Debris	scalar *Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar *Visual	NONE	NONE	NONE	NONE
Appearance	scalar *Visual	NORML	NORML	NORML	NORML
Odor	scalar *Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar *Visual	>2	NEG	NEG	NEG
Free Water	scalar *Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D445	32	33.1	33.2	33.5

SAMPLE IMAGES



Color

Bottom



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PLS0000652 **Received** : 07 Dec 2023
Lab Number : **06028593** **Diagnosed** : 15 Dec 2023
Unique Number : 10778384 **Diagnostician** : Mike Johnson
Test Package : IND 2 (Additional Tests: FT-IR, PQ, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

HEXION - DIBOLL PLANT
 100 W BORDEN DR
 DIBOLL, TX
 US 75941

Contact: DENISE ROBERTSON
 denise.robertson@hexion.com;mike.johnson@amrri.com

T: (936)829-8029
 F: (936)829-8003