

PROBLEM SUMMARY

Nachine Id NMARLEN LEYBOLD SV200 (S/N U141100116) Component


Vacuum Pump Fluid USPI VAC 100 (--- GAL)

16) No.723 Dect023

ISO

Sample Rating Trend

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	ABNORMAL					
Particles >4µm	ASTM D7647	>5000	A 33244	1 1984					
Particles >6µm	ASTM D7647	>1300	6 5253	1102					
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<u> </u>	A 21/17/12					

Customer Id: TYSKAN Sample No.: USPM31970 Lab Number: 06028704 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u> There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

05 Nov 2023 Diag: Doug Bogart

WATER

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.All component wear rates are normal. Appearance is hazy. There is a high amount of silt (particulates < 6 microns in size) present in the oil. There is a moderate concentration of water present in the oil. Additive levels indicate the addition of a different brand or type of oil. Confirmed. The AN level is acceptable for this fluid.





OIL ANALYSIS REPORT

Machine Ic N MARLEN LEYBOLD SV200 (S/N U Component

Vacuum Pump

USPI VAC 100 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SIS REPC)RT					ISO
S/N U141100	116)					
	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,					
			Nov2023	Dec2023		
SAMPLE INFORM		method	limit/base		history1	history2
Sample Number		Client Info		USPM31970	USPM31279	
Sample Date		Client Info		02 Dec 2023	05 Nov 2023	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		0 N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base			history
					history1	history2
Iron	ppm	ASTM D5185m	>20	0	0	
Chromium	ppm		>20	0	0	
Nickel	ppm	ASTM D5185m	>20	0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>20	<1	1	
Lead	ppm	ASTM D5185m	>20	0	0	
Copper	ppm	ASTM D5185m	>20	<1	<1	
Tin	ppm	ASTM D5185m	>20	<1	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	0	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	0	<1	0	
Calcium	ppm	ASTM D5185m	0	<1	0	
Phosphorus	ppm	ASTM D5185m	1800	645	1 21	
Zinc	ppm	ASTM D5185m	0	0	10	
Sulfur	ppm	ASTM D5185m	0	345	<u> </u>	
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	5	4	
Sodium	ppm	ASTM D5185m		1	<1	
Potassium	ppm	ASTM D5185m	>20	<1	<1	
Water	%	ASTM D6304	>.1	0.052	▲ 0.535	
ppm Water	ppm	ASTM D6304	>1000	529	▲ 5350	
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	▲ 33244	▲ 11984	
Particles >6µm		ASTM D7647 ASTM D7647	>1300	▲ 5253	1102	
Particles >14µm		ASTM D7647 ASTM D7647	>160	94	24	
Particles >21µm		ASTM D7647		11	6	
Particles >38µm		ASTM D7647	>10	0	1	
Particles >71µm		ASTM D7647		0	0	
Oil Cleanliness		ISO 4406 (c)	>19/17/14	22/20/14	21/17/12	
		(0)			·····	

Sample Rating Trend

ISO

Acid Number (AN)

FLUID DEGRADATION

method mg KOH/g ASTM D8045 0.05

limit/base

current

0.094

0.14

history1

history2



Acid Number

7 00

6.00 (BHO) 5.00 Ê 4.00

-e 3.00 Acid Nur 700

1.00

600

5000

3000 Water

2000

100 Π

220

200

180

() 160 ද ද (140

120

10

80

Ē

Abnormal

OIL ANALYSIS REPORT

method


limit/base


current


history1

history2

VISUAL







0.00 Water (KF) A Viscosity @ 40°C

Report Id: TYSKAN [WUSCAR] 06028704 (Generated: 12/19/2023 10:27:09) Rev: 1

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: WILLIAM KENNEDY - TYSKAN

T:

F: