

OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



RECO TYSNEW H-15 (S/N IQC314VH717/19180-240)

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

32014 Aug/2015 Nov/2016 Jan/2018 Agr/2019 Jun/2020 Sep/2021 Des/2022						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0003917	USP0000180	USP250134
Sample Date		Client Info		05 Dec 2023	06 Sep 2023	14 Jun 2023
Machine Age	hrs	Client Info		118277	118134	117016
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	0
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		<1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	0
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	<1	0	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		0	<1	0
Calcium	ppm	ASTM D5185m		0	<1	0
Phosphorus	ppm	ASTM D5185m		<1	<1	0
Zinc	ppm	ASTM D5185m		0	3	0
Sulfur	ppm	ASTM D5185m	50	67	77	87
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	2	<1
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	<1	2	<1
Water	%	ASTM D6304	>0.01	0.003	0.004	0.004
ppm Water	ppm	ASTM D6304	>100	31	49.0	43.8
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2647	1860	2092
Particles >6µm		ASTM D7647	>2500	451	543	462
Particles >14µm		ASTM D7647	>320	11	26	11
Particles >21µm		ASTM D7647	>80	2	6	3
Particles >38µm		ASTM D7647	>20	0	0	1
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/18/15	19/16/11	18/16/12	18/16/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.015	0.03	0.013



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number **Unique Number**

: 06028717 : 10778508 Test Package : IND 2

: USP0003917

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: 07 Dec 2023 Received Diagnosed Diagnostician

: 10 Dec 2023 : Doug Bogart

PLANT 1 NEW HOLLAND, PA US 17557

Contact: ROGER GOOD roger.good@tyson.com T: (800)755-4572

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (402)423-6661