


PROBLEM SUMMARY


ULTRA COOLANT [1397865]

Component

Compressor



COMPONENT CONDITION SUMMARY



INGERSOLL RAND MOX1005726 - GRAND RIVER ASEPTIC

RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status				ATTENTION	NORMAL	ABNORMAL		
Barium	ppm	ASTM D5185m	500	43	966	967		
Visc @ 40°C	cSt	ASTM D445	49.4	33.86	50.3	49.9		

Customer Id: UCAIRBYR Sample No.: UCH06029485 Lab Number: 06029485 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

07 Aug 2023 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



30 May 2023 Diag: Doug Bogart

DIRT



The oil is near the end of it's useful service life, recommend schedule an oil change. Resample at the next service interval to monitor. The lead level is abnormal. All other component wear rates are normal. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is approaching the top-end of the recommended limit.






OIL ANALYSIS REPORT

ULTRA COOLANT [1397865]

INGERSOLL RAND MOX1005726 - GRAND RIVER ASEPTIC

Component

Compressor



DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Waar

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil


▲ Fluid Condition

The oil viscosity is lower than normal. Additive levels indicate the addition of a different brand, or type of oil. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06029485	UCH05929740	UCH05868013
Sample Date		Client Info		09 Nov 2023	07 Aug 2023	30 May 2023
Machine Age	hrs	Client Info		5909	5757	4882
Oil Age	hrs	Client Info		152	0	4882
Oil Changed		Client Info		Not Changd	Changed	Not Changd
Sample Status				ATTENTION	NORMAL	ABNORMAL
CONTAMINATION	١	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	2	2
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>25	0	0	0
Lead	ppm	ASTM D5185m	>25	0	20	<u>^</u> 29
Copper	ppm	ASTM D5185m	>50	<1	3	2
Tin	ppm	ASTM D5185m	>15	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	500	43	966	967
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	0	0	<1	<1
Calcium	ppm	ASTM D5185m	0	0	2	<1
Phosphorus	ppm	ASTM D5185m	20	150	2	5
Zinc	ppm	ASTM D5185m	0	0	0	<1
Sulfur	ppm	ASTM D5185m	200	68	372	345
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	14	3	△ 63
Sodium	ppm	ASTM D5185m		0	3	1
Potassium	ppm	ASTM D5185m	>20	0	<1	1
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.56	0.065	△ 0.134



OIL ANALYSIS REPORT




VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	49.4	▲ 33.86	50.3	49.9
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						


Ferrous Alloys


Bottom

GRAPHS

Non-ferrous Metals











Certificate L2367

Laboratory Sample No. Lab Number Unique Number : 10779276 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 06029485

: UCH06029485

Recieved : 08 Dec 2023 Diagnosed : 19 Dec 2023 Diagnostician : Jonathan Hester

AIR TECHNOLOGIES INC (GR) 160 84TH STREET SW SUITE 1

BYRON CENTER, MI US 49315

Contact: STEPHANIE CLAYPOOL stephanie.claypool@aircompressors.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (616)281-6737

T: