

PROBLEM SUMMARY

Sample Rating Trend

manufacture de la constant de la con

ISO




HOWDEN TYSWAL B-1 (S/N MK 46/WRV255/16536/823)

Refrigeration Compressor

USPI ALT-68 SC (160 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ATTENTION	NORMAL	NORMAL				
Particles >4µm	ASTM D7647	>10000	<u> </u>	1433	1856				
Particles >6µm	ASTM D7647	>2500	2818	273	532				
Oil Cleanliness	ISO 4406 (c)	>20/18/15	1 21/19/13	18/15/12	18/16/12				

Customer Id: TYSWALAR Sample No.: USP0004060 Lab Number: 06030012 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

26 Aug 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



16 May 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



03 Feb 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

HOWDEN TYSWAL B-1 (S/N MK 46/WRV255/16536/823)

Component

Refrigeration Compressor

USPI ALT-68 SC (160 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

2013 0x2014 Jun2016 0x2017 Jun2019 Rep2020 Sep2021 0x2022								
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2		
Sample Number		Client Info		USP0004060	USP0000380	USP243499		
Sample Date		Client Info		05 Dec 2023	26 Aug 2023	16 May 2023		
Machine Age	hrs	Client Info		89538	88533	0		
Oil Age	hrs	Client Info		0	0	0		
Oil Changed		Client Info		N/A	N/A	N/A		
Sample Status				ATTENTION	NORMAL	NORMAL		
WEAR METALS		method	limit/base	current	history1	history2		
Iron	ppm	ASTM D5185m	>8	0	0	0		
Chromium	ppm	ASTM D5185m	>2	0	0	0		
Nickel	ppm	ASTM D5185m		0	0	<1		
Titanium	ppm	ASTM D5185m		<1	0	0		
Silver	ppm	ASTM D5185m	>2	0	0	0		
Aluminum	ppm	ASTM D5185m		0	0	<1		
Lead	ppm	ASTM D5185m	>2	0	0	0		
Copper	ppm	ASTM D5185m		0	0	0		
Tin	ppm	ASTM D5185m	>4	0	0	<1		
Vanadium	ppm	ASTM D5185m		0	0	0		
Cadmium	ppm	ASTM D5185m		0	0	0		
ADDITIVES		method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m		0	0	0		
Barium	ppm	ASTM D5185m		0	0	0		
Molybdenum	ppm	ASTM D5185m		0	0	0		
Manganese	ppm	ASTM D5185m		0	0	<1		
Magnesium	ppm	ASTM D5185m		0	<1	0		
Calcium	ppm	ASTM D5185m		0	0	0		
Phosphorus	ppm	ASTM D5185m		0	1	0		
Zinc	ppm	ASTM D5185m		0	0	0		
Sulfur	ppm	ASTM D5185m	50	10	138	191		
CONTAMINANTS		method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m	>15	2	1	<1		
Sodium	ppm	ASTM D5185m		0	0	<1		
Potassium	ppm	ASTM D5185m	>20	1	<1	<1		
Water	%	ASTM D6304	>0.01	0.003	0.004	0.006		
ppm Water	ppm	ASTM D6304	>100	27	41.5	60.1		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2		
Particles >4µm		ASTM D7647	>10000	<u> </u>	1433	1856		
Particles >6µm		ASTM D7647	>2500	<u>A</u> 2818	273	532		
Particles >14μm		ASTM D7647	>320	50	31	32		
Particles >21µm		ASTM D7647	>80	5	12	7		
Particles >38μm		ASTM D7647	>20	0	1	0		
Particles >71µm		ASTM D7647	>4	0	0	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u>^</u> 21/19/13	18/15/12	18/16/12		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2		

Acid Number (AN)

0.014


0.012

mg KOH/g ASTM D974 0.005

0.014



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: USP0004060 : 06030012

: 10779803 Test Package : IND 2

: 08 Dec 2023 Received Diagnosed Diagnostician

: 12 Dec 2023 : Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

TYSON - WALDRON- USP

WALDRON, AR US

Contact: DANNY HOUSTON danny.houston@tyson.com

T: (479)637-2121 F: (479)637-5602