

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



GZJ00403

Component Biogas Engine

PETRO CANADA SENTRON CG 40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. (Customer Sample Comment: 45 gallons added) $% \left(\left(1-\frac{1}{2}\right) \right) \right) =0$

Fluic

Wear

All component wear rates are normal.

Contamination

Fuel content negligible. There is no indication of any contamination in the oil.


Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0836467	WC0836469	WC0836475
Sample Date		Client Info		05 Dec 2023	21 Nov 2023	14 Nov 2023
Machine Age	hrs	Client Info		119064	118865	118697
Oil Age	hrs	Client Info		4	299	111
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
	NI	and the set	11.0011/10.000	-	-	
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>45	4	6	2
Chromium	ppm	ASTM D5185m	>2	<1	<1	<1
Nickel	ppm	ASTM D5185m	>2	0	<1	0
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	2
Lead	ppm	ASTM D5185m	>5	1	3	1
Copper	ppm	ASTM D5185m	>14	<1	3	1
Tin	ppm	ASTM D5185m	>13	0	3	2
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	1	<1	0
Barium	ppm	ASTM D5185m	1	0	<1	0
Molybdenum	ppm	ASTM D5185m	2	1	2	0
Manganese	ppm	ASTM D5185m	1	<1	<1	<1
Magnesium	ppm	ASTM D5185m	9	0	18	19
Calcium	ppm	ASTM D5185m	2712	2698	2923	2839
Phosphorus	ppm	ASTM D5185m	292	249	296	301
Zinc	ppm	ASTM D5185m	342	345	357	369
Sulfur	ppm	ASTM D5185m	2575	3412	3965	3479
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>200	11	192	121
Sodium	ppm	ASTM D5185m		0	<1	3
Potassium	ppm	ASTM D5185m	>20	2	2	1
Fuel	%	ASTM D3524	>4.0	0.0	0.3	0.3
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624	>20	3.2	5.3	4.8
Sulfation	Abs/.1mm	*ASTM D7415	>30	13.6	19.0	16.9
Guilation	7.000/.1111111					
FLUID DEGRAD		method	limit/base	current	history1	history2
FLUID DEGRADA	ATION					
FLUID DEGRADA	ATION Abs/.1mm	*ASTM D7414	>25	7.3	11.3	9.6
FLUID DEGRADA	ATION					




OIL ANALYSIS REPORT









	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
	Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
	Silt	scalar	*Visual	NONE	NONE	NONE	NONE
	Debris	scalar	*Visual	NONE	NONE	NONE	NONE
~	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Sep 18/23 0ct30/23	Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Sep	Odor	scalar	*Visual	NORML	NORML	NORML	NORML
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
	Free Water	scalar	*Visual		NEG	NEG	NEG
MA	FLUID PROPERT	IES	method	limit/base	current	history1	history2
Vh	Visc @ 100°C	cSt	ASTM D445	13.5	13.3	13.5	13.4
	GRAPHS						
	Iron (ppm)				Lead (ppm)		
	100 Severe			10	Develo		
Sep 18/23 0ct30/23	80 - C				10.000000000000000000000000000000000000		
Se O				E d	Abnormal	Λ.	
	20				4	. A A	A AA
	12-1-	\sim	m	\sim	Lm	VVI	NVV
	Feb21/23 Mar27/23 May1/23 Jun5/23	Jul10/23	Aug 15/23 . Sep 18/23 . Def 30/23 .		Feb21/23 Mar27/23 May1/23	Jun5/23 Jul10/23 Aug15/23	Sep18/23 0ct30/23
	Feb2 Mar2 May	llut	Sep1		Feb2 Mar2 May	Jun Jul	Sep1 0ct3
~ ~ ~	Aluminum (ppm)				Chromium (p	pm)	
	20 Severe			1111	Severe		
	15					co hora hara ha	0010001000
23	a 10 Abnormal			udd,	Abnormal		
Sep18/23 0ct30/23	5+		A		2 - 6		
2	m	~~	Mm	\sim	1000	~~~~	
		1/23	123	(53 53 53	(23	//23
	Feb21/23 Mar27/23 May1/23 Jun5/23	Jul10/23	Aug 15/23 Sep 18/23 Def 30/23		Feb21/23 Mar27/23 May1/23	Jun5/23 Jul10/23 Aug15/23	Sep18/23 0ct30/23
	Copper (ppm)				Silicon (ppm)		
	³⁰ Severe			500			
~~~	25-			400		111	1
	20 - [] 15 - <b>Abnormal</b>			E 300		+/+/+	AA
	10			² 200	Abhormai	VVI	/ 1/ 4
53	5			100	· V · ·	· · · · · · · · · · · · · · · · · · ·	v 1
Sep 18/23 0ct30/23		23			³	23	23
	Feb21/23 Mar27/23 Jun5/23	Jul10/23	Aug 15/23 Sep 18/23 Def 30/23		Feb21/23 Mar27/23 May1/23	Jun5/23 Jul10/23 Aug15/23	Sep18/23 0ct30/23
	⊥ ≤ 2 Viscosity @ 100°C		A S	)		4	S O
	18 _T	2000.000.000	13333335555577		Base Number		
	Abnormal			(B) HO (B) HO (B) Bu) ta 6.( Numu 4.( 2.(	Bare #	٨	
0				y 8.0	-A	VWZ	VNV
	Base Abnormal		Auron	6.0 mm		•	
	12- <b>8</b>			2 T.0 82 2.0	, 		
				0.0	)		
	Feb21/23 Mar27/23 May1/23 Jun5/23	Juli 0/23	Aug 15/23 Sep 18/23 Oct30/23		Feb21/23 Mar27/23 May1/23	Jun5/23 Jul10/23 Aug15/23	Sep18/23 0ct30/23
	Ma M	JL	Se	í	Ma Ma	Jr Ju	Se
aboratory	: WearCheck USA - 5				3		BIOENERG
ample No. ab Number		Recieve		Dec 2023 Dec 2023		74265 Bombir	
ab Number nique Number		Diagnos Diagnos		athan Hester	r		Boardman, OF US 9781
est Package	: MOB 2 ( Additional )					Contact: I	Blain Middleto
	,		300-237-1369			bmiddleton@a	

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

F:

T: (541)481-3232